







Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	
A-1	SUB-STATION	765 kV											
		400 kV											
		220kV	220/33 kV Shendra DMIC ,GIS District-Aurangabad (WIP) (Spill over from 2022-23)	220/33 KV Bidkin DMIC, GIS District-Aurangabad	220/33kV Sarul (BR Sanctioned) (MSEDCL/RE)	220/132/33 kV Dahegaon Bangla (Murni)(New)	220/132/33 kV S/ s at Karmad (New)						
					220/132kV Station Narsi	220/132/33 kV S/s at Gandheli (New)							
		132kV	132/33kV Ida Jawala Dist- Osmanabad (WIP)	132/33kV Ajani BK (Previously Talegaon) Dist-Latur (New) (MSEDCL/RE)	132/33 kV Sawana S/s, Tal. Sengaon, Dist. Hingoli	132/33 kV/s at Kada S/s Dist. Beed (New) / Pimpla/ Dongargaon	132/33 kV S/S at Takarvan, Majalgaon, Beed (New)	132/33 kV S/s at Golwadi Kanchanwadi, Dist. Sambhaji Nagar (New)	132/33 kV S/s at Karodi, Dist. Sambhaji Nagar (New)	132/33 kV S/s at Mudkhed Substation, Nanded (New)	132/33kV Ladzari (MSEDCL/RE)		
			132/33kV Samudral Substation, Dist-Osmanabad (WIP)	132/33kV Barashiv (Hanuman Nagar/Aundha) District- Hingoli (MSEDCL Demand received)	132/33 kV Mahur, District-Nanded (BR Sanctioned)		132/33 kV S/s at Belora, Shirur, Beed (New)	132/33 kV Substation at CADA, Dist. Sambhaji Nagar (New)	132/33 kV S/s at Bazar Sawangi, Dist. Sambhaji Nagar (New)				
				132/33kV Selu									
		110kV											
		100kV											
				765 kV									
400kV													
220kV	LILO on one circuit of 220 kV DC line from 400 kV Aurangabad (PG) – Shendra at 220kV Shendra (AURIC ) (DMIC Project) – 8 Km			LILO of 220 kV Chitepimpalgaon - Chitegaon @Bidkin DMIC - 5 kms	LILO on 220kV Beed-Manjarsumbha line -20km with HTLS for Sarul S/s	220kV LILO on Waluj Chitegaon line for 220kV Dahegaon SS (New)	220 kV Thapitanda - Waluj LILO at 220 kV Karmad-12km (New)						
					220kV D/C LINE from 220220kV Krishnoor to Narsi sstn	LILO of 220 kV PGCIL Shendra line at 220 kV Gandheli.(New)	LILO of 220 kV PGCIL Shendra DMIC line for 220 kV Karmad s/s (New)						
132kV	LILO of 132kV Bhoom-Paranda line at Ida Jawla S/S - 2km (WIP)			LILO of 132kV Harangul-Chakur at Ajani Bk. (New)	LILO ON 132kV Waghala Narsi (dhuppa) line @220kv Narsi	132kV Chittegaon - Paithan LILO at Dahegaon Bangla	132 kV Line from 220kV Georai S/s to Takarvan – 35 kms	LILO on 132 kV Padegaon - Paithan at 132 kV Golwadi (New)	LILO ON 132KV Walunj - Padegaon AT KARODI	LILO of 132 kV Waghala-Umri line at Mudkhed (New)	LILO of 132kV Girvali-Ahmedpur at Ladzari (New)		
	LILO of 132kV Killari-Narangwadi line at Samudral S/S - 5km (WIP)			LILO of 132 kV Kurunda - Hingoli line at Barashiv S/s- 16km	Reorientation of 132kV Mukhed - Narsi Line & Narsi Kundalwadi line at 220kv Narsi	132kV Chittegaon - to Dahegaon Bangla D/C line	LILO on 132 kV Raimoha - Beed line at Belora – 5 kms	132 kV Chikalthana CADA Line (EHV Cable (New)	LILO ON 132KV Swawangi - Kagzipura AT Bbazar sawangi				
				LILO of 132kV Partur-Parbhani at Selu (New)	132 kV Gunj - Mahur SCDC line - 25 kms	132 kV line from 220/132/33 kV Gandheli s/s to 220 kV Shendra s/s (New)							
					LILO ON 132kV Jam Bazar - Washim line @132kv Sawana	132 kV line from 220/132/33 kV Gandheli s/s to 132kV Satara s/s (New)							
						LILO ON Ahamadnar - Pathardi Line at 132KV KADA/PIMPLA/DONGARGAON							
110kV													
100kV													
B	LINK LINES	765kV											
		400kV	400kV Bhusawa-II - Waluj at Tapthitanda -177km (Balance work of 400kV Thapati Tanda) (WIP)										
		220kV	LILO on one circuit of Chikhali - Jalna line at 220 kV Nagewadi – 30 ckt kms (Remaining scope of Nagewadi Work)	220kV Nagewadi - Bhokardan DC- 50 km (WIP)	220kV Georai-Partur DC line -80km								
				220 kv Interconnection between 220KV Murud -Tuljapur and Barshi Osmanabad (0.5 km )	LILO of 220 kV Jalna- Chikhali Ckt- 2 at 220 kV Nagewadi Substation (New)								
		132kV	132kV Ambad – Ghansawangi at Partur -30 km (WIP)	Interconnection Between 132 KV Hingoli Sengaon CKT-1 & 132 KV Yeldari Risod ( 13 km )	132 kV Basmat- Jangamwadi DC line (New) 25km	132kV SCDC Line from 220kV Deogaon Rangari-Kannad - 30km	LILO on 132kV Chittegaon-Deolai(Satara)-line at 220kV Shendra - 10km						
		Georai - Rajpimprie LILO at 220 kV Georai S/s - 5 kms		Patoda - Raimoha SCDC (GEC)-30km									

Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	
						LILO Kharda - Ashti at Patoda (GEC)-30km							
		110kv											
		100kv											
		220kv											
C-1	2nd CIRCUIT STRING	132kV	132kV Nilanga-Omerga	132kV Jalkot-Udgir									
			132kV Kharda-Bhairvnath (RE)	132kV Bhokardhan - Rajur- 26km									
			132kV Bhokardan - Jafrabad - 29km (WIP)	132kV Parbhani - Pathri- 48km									
			132kV SAT - Gangapur-27km	132 kV Jalna Old - Partur - 49 kms (New)									
			132kV Georai - Mahakala- 22km	132 kV Gangapur- Vaijapur -40 km (New)									
			132 kV Bhokar - Tamsa - 24 kms (New)										
			132 kV Bhokar - Himayatnagar – 45 Km (New)										
		110kV											
		100kV											
		400kV											
C-2	HIGH AMPICITY CONDUCTOR	220kV	220kV Beed-Patoda- Manjarsumbha - 45km (RE)										
			220kV Beed-Patoda -35km (RE)										
		132kV	132kV Nagewadi to 132kV Jalna MIDC	132kV Ujani-Tulajapur-Naldurg-Solapur DC line -107kms including LILO portion									
			132kV Jalna MIDC-Jalna line (via Rajur ckt-II)	132kv Shendra - Chikalthana - 12km									
			132kV Partur to Partur DC line (RE)										
		132kV Harangul-Ausa- Ujani and 132 kV Harangul-Niwali- Ujani including LILO portion of Ausa and Niwali -79ekt kms -Tulajapur-Naldurg-Solapur DC line -107kms including LILO portion (New)											
		110kV											
		100kV											
		220kV											
C-3	REPLACEMENT OF CONDUCTOR	132kV											
C-4	CONVERSION OF LINE	220kV											
		132kV											
		400kV											
D-1	CREATION OF NEW LEVEL	220kV	Patoda (2X100)MVA 220/132kV (RE)	Shendra DMIC (2X100)MVA 220/132kV									
				400kV Waluj S/s 2x100 MVA , 220/132kV									
		132kv											
		33kv	33 kV level creation at 220 kV substation Georai with 2X25 MVA, 220/33 kV (New)	Padegaon (2X50)MVA 220/33kV									
D-2	ADDITION OF ICT	765kV		1x1500MVA ,765/400kV Ektuni									
		400kV	Thaptitanda (3X 167)MVA 400/220kV	Kumbhargaoon (3X167)MVA 400/220kV									
		220kv		Narangwadi (1 x 100 MVA), 220/132 kV (RE)	Paranda(1X100)MVA 220/132kV (RE)								
				1 x 200 MVA, 220/132 kV ICT at 220 kV Jalna S/s ( New)	Tuljapur (1x100)MVA220/132kV								
			1 x 200 MVA, 220/132 kV ICT at 220 kV Nagewadi S/s ( New)	Jalkot(1x100)MVA 220/132kV (RE)									













NAGPUR

Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	
A-1	SUB-STATION	765kV											
		400kV		Evacuation arrangement for 2X660 MW generation of Koradi									
		220kV	220/132/33 kV New Pardi District-Nagpur (WIP) (Spill Over)	220/33 kV Kadholi , District Nagpur	220/33 kV Pachgaon (Kuhi), District-Nagpur	220/132/33 kV Yenwa ,District-Nagpur	220/33 kV Nagardhan S/S, Dist. Nagpur (NEW)						
			220/132/33 kV Mankapur District- Nagpur (WIP)										
		132kV	220/132/33kV Nagbhid , District- Chandrapur Back charged										
			132/33 kV Jat Tirodi ,Dist- Nagpur (WIP) (Spill Over)	132kV Etapalli (Upgradation from 66kV along with existing 66kV line)	132/33 kV Bazargaon ,District-Nagpur	132/33kV Deori, District- Gondia	132 kV Substation at Goregaon in Gondia District.(New)	132 kv Bhamragarh S/S.(New)	132 kV Kurla near Nagri (under Warora Division) (New)				
			132/33 kV Sironcha, District- Gadchiroli Back charged on 33kv Level 20.06.2022	132kV Kurkheda Dist. Chandrapur									
			132 /33 kV Lendra Park (GIS) District- Nagpur	132/33 kV Mihan, District- Nagpur (BR Sanctioned)									
		110kV											
		100kV											
A-2	ASSOCIATED LINES	765kV											
		400kV											
		220kV	220 kV Uppalwadi - Pardi DC UG cable line 12.5 (Route Km) WIP (Spill Over)	L.I.LO of one ckt of 220 kV Kanhan-Bhandara line for 220 kV Kadholi - 10 km	L.I.LO of one ckt of 220kV Kanhan – Umred DCDC Line for Pachgaon s/s - 15 km	L.I.LO on 220 kv Kalmeshwar-Warud DC line for 220 kV Yenwa- 0.5 Km	L.I.LO on 220 KV Koradi II-Kaulewada D/C Tr. Line at Nagardhan (NEW)						
			Koradi-II to Mankapur (U/G)-6kms WIP				L.I.LO on 220 kV Kanhan-Bhandara line at Nagardhan (NEW)						
			220 kV DC Uppalwadi-Mankapur U/G-9 Km WIP				L.I.LO on 220 kV Kanhan-Ultratech line. at Nagardhan (NEW)						
		132kV	220 kV DC line from 220kV Umred S/s - 46 Km for 220kV Nagbhid WIP (Spill Over)										
			L.I.LO on Mankapur - Hingana I-for 132 kV Lendra ss - 7.746 km (O/H-3.25km,U/G-4.5km)	132kV Lakhandur - Morgaon Arjuni @ Kurkheda - 37 Km	L.I.LO on 132 kV Ambazari-Karanja line for 132kV Bazargaon - 300 mtr.	L.I.LO of 132 kV Amgaon - Gondia for 132 kV Deori ss - 41 km		132kV line from Allapali TO Bhamragad					
			Interconnection between 220 kV New Pardi and 132 kV Pardi s/s-2 ckt KM WIP (Spill Over)	L.I.LO on 132 kV Hingna II to Khapri line for Mihan S/s - 1 kms									
			132 kV DC undergroundcable from 132 kV Pardi s/s to Jat Tarodi s/-10.0 kms WIP (Spill Over)										
			132 kV SCDC line from Kistampeth (Telangana) for 132kV Sironcha -35 ckt kms WIP										
110kV													
100kV													
		765kV											
		400kV		400 KV D/C TL from GT unit 11 & 12 to 400 KV Koradi I (1.2 Km) (NEW)					Shfting of 400kV Koradi I - Bhusawal line from 400kV Koradi - I to 400kV Koradi - II				
		220kV Koradi -II - Buttibori - III DC Line 105.ckm	220kV DCDC UG cable from GMR S/S to Sai Wardha S/S- 3.5 Km (Evacuation of GMR EMCO Gen) WIP	Interconnection of 220 kV Chandrapur GCR –Sicom line with 220 kV Virur-Gadchiroli. (99 Ckt km(49.5km)) (NEW)			220 KV Sicom-Ballarshah DCDC line (New) SHIFTED FROM 132KV						





NASIK

Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34
A-1	SUB-STATION	765 KV										
		400kV		400/220 kV Pimpalgaon District-Nashik (BR- Sanctioned)		400/220kV Malegaon(Saundane)						
		220kV		220/132 kV Nandurbar, District-Nandurbar	220 kV Ghogergaon Dist: Ahmadnagar (NEW)	220/33 kV Jalgaon MIDC Dist: Jalgaon (NEW)	220/132/33kV Akarale	220/33 kV Shirdi Dist: Ahmadnagar (NEW)	Upgradation of 132 kV Shirpur s/s to 220 kV Shirpur Dist: Dhule (NEW)	220/33 kV Saykhindi Dist: Ahmadnagar (NEW)	220/33kV Vilholi Dist: Nashik (NEW)	220/33 kV Dhotre Dist: Ahmadnagar (NEW)
				Upgradation of 132kV IGATPURI - TO 220kV GIS		220/33 kV Asali Dist: Dhule (NEW)		220/33 kV Kone Dist: Nashik (NEW)	220/33 kV Chinchvihire Dist: Ahmadnagar (NEW)			
				220/33 kV Deosane, District-Nashik (BR- Sanctioned)								
				220/132/33 kV Supa MIDC District- Ahmednagar (BR- Sanctioned)								
				220/33kV Shrirampur, District-Ahmednagar (BR- Sanctioned)								
		132kV	132/33kV Dhanora ,District-Jalgaon (WIP)	132kV Navapur Dist-Nandurbar (WIP)	132/33kV Mendhvan, District-Ahmednagar	132/33 kV Shirud Dist: Dhule (NEW)	132/33 kV Akalkuwa Dist: Nandurbar (NEW)	132/33 kV War Dist: Dhule (NEW)	132/33 kV Patoda Dist: Nashik (NEW)	132 kV Sheware Dist: Nashik (NEW)	132/33 kV Boris Dist: Dhule (NEW)	
				132 /33 kV Kanashi Dist: Nashik (NEW)	132/33kV Pimpalner (MSEDCL/RE)				132/33 kV Ajang Dist: Nashik (NEW)			
				132/33 kV Shirsoli Dist: Jalgaon (NEW)								
110kV												
100kV												
765kV												
A-2	ASSOCIATED LINES	400kV		LILO 400kV A'bad PG-Boisar (PG) DC line at 400 kV Pimpalgaon -3 km		LILO of both ckt. 400kV Dhule-Babhaleshwar D/C Lines at proposed 400kV Malegaon (Saundane) SS -46 km	LILO on both ckt 400kV Sardarsrovar-Dhule D/C line at Balsane - 36 ckm					
		220kV		220 kV DC line by making LILO on 220 kV Dondaicha - Jamde line one ckt - 50 ckt kms @ Nandurbar MIDC		LILO on both circuits of 220 kV Malegaon-Kalwan Line at new proposed 400kV Malegaon (Saundane) SS-10km	220kV Balsane -Shivajinagar DC line - 36 ckm					
				LILO on 220kV Raymond - Washala @ Proposed 220/132kV Igatpuri 10ckm		LILO on both circuits of 220 kV Malegaon-Manmad at new proposed Soundane SS-5km	220kV Balsane -Vikharan DC line - 24 ckm					
				220kV M/C line by making both ckt LILO on 220 KV Eklahare-Pimpalgaon Line to 400/220 KV Pimpalgaon S/s-13.762 kms (NEW)		LILO on both ckt of 220kV Malegaon-Satana at new proposed Soundane SS 220kV Soundane-Satana-15km	220kV MC line by making LILO on 220kV Eklahare-Navsari (ckt 2) line- 2.25km & proposed 220kV Eklahare-Reliance life science line-1.5km to proposed 220kV Akrale ss (NEW)					
				LILO on one circuit of 220kV Nashik (OCR) - Navsari D/C line at proposed 220/33kV Deosane substation - 15 Km		LILO on 220kV Dondaicha - Amalner line @ proposed 220kV Asali S/s. 37km						
				LILO of one circuit of 220 kV Ahmednagar - Bhose DC line at Supa - 20 Km								
				LILO on 220 kV Babhaleshwar - Bhenda (S/C) line at 220 kV Shrirampur S/s. - 5 ckm								









Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	
		132kV		Shivajinagar - Sakri - Dhule - 80km									
				132kV Malkapur-Khadka line via VaragaonTap-47 km (RE)									
				132kV Pimperkhed-Chalisingaon									
				132kV Manmad-Pimperkhed									
				132kV Manmad-Chalisingaon									
				132kV Khaprata-Sinnar									
			220/132kV Kalwan (Bhendi) - 132kV Kalwan- 8km										
		110kV											
		100kV											
C-3	REPLACEMENT OF CONDUCTOR	400kV											
		132kV											
C-4	CONVERSION OF LINE	220kV											
		132kV	Conversion of 132 kV Babhleshwar - Sangamner SCSC line into DCDC -34km	Conversion of SCSC to DCDC of 132 kV Dhule-Sakri line (NEW)	Conversion of 132kV SCSC to DCDC of Yawal-Chopda Line (NEW)								
D-1	CREATION OF NEW LEVEL	400kV											
		220kV			33 kV level creation at 220 kV Amalner s/s (NEW) 2x50MVA 220/33kV	33 kV level creation at 220 kV Nandurbar ( Bhaler) s/s (NEW)	Pimpalgaon (2 X 50)MVA 220/33kV (NEW)						
		132kV	2x50MVA 132/33kV at 132kV Ozar										
			Pimpalgaon (1 X 50)MVA 132/33kV										
		33kV											
D-2	ADDITION OF ICT	765kV											
		400kV	Khadka (3X105)MVA 400/220kV (WIP) (spill Over)	Additional 3X167 MVA, 400/220/33kV ICT with extension of RRS upto existing 167MVA, 400/220/33kV Spare ICT unit at 400kV R.S. Dhule (NEW)									
			Chalisingaon (1X200)MVA 220/132kV (WIP) (spill Over)										
			1X100 MVA 220/132kV ICT 220kV Kekatnimbhora (RE)										
		220kV	1X100 MVA 220/132kV ICT 220kV Shivajinagar.										
D-3	REPLACEMENT	400kV		Dhule 3 X (167-105)MVA 400/220 kV (third ICT replacement existing 2x500MVA +1x315)	Babhleshwar 3x(167-105)MVA 400/220kV								



NASIK

Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	
D-5	TRANSFORMER REPLACEMENT	220kV		2x(50-25)MVA 220/33kV TF at 220kV Bambhori	2x(100-50)MVA 220/33kV TF Babhaleshwar (NEW)								
				Dondaicha 1x(50-25)MVA, 220/33kV	1x(50-25)MVA 220/33kV TF Dhule (NEW)								
				Kundane 1x(50-25)MVA, 220/33kV MSKVY									
		132kV		1x(50-25)MVA 132/33kV TF Ramachepimplas	2x(50-25)MVA 132/33kV TF Bhodhwad (NEW)								
				1x(50-25)MVA 132/33kV TF Ghodegaon	1x(50-25)MVA 132/33kV TF Visarwadi (NEW)								
				1x(50-25)MVA 220/33kV TF Manamd	1x(50-25)MVA 132/33kV TF Chandwad (NEW)								
				1x(50-25)MVA 132/33kV TF Sawda	2x(50-25)MVA 132/33kV TF Nimbhora (NEW)								
				2x(50-25)MVA 132/33kV TF Parola	2x(50-25)MVA 132kV TF ECR Deepnagar (NEW)								
				2x(50-25)MVA 132/33kV TF Dharangaon									
			110kV										
	100kV												
E-1	NEW REACTOR	400kV 220kV											
E-2	REPLACEMENT REACTOR	400kV		1 X (125 - 50) MVAr, Khadka									
				1 X (125 - 80) MVAr, Babhaleshwar									
				2x(80- 50) MVAr Line Reactors (for Akola & Koradi lines) at 400KV Khadka SS (NEW)									
	220kV												
	220kV												
	132kV												
F	CAPACITOR	33kV		14 No's - 255 MVAr									
				6 Nos. -160 MVAR PAHSE - VI									
	STATCOM					300MVAr at 400KV DHULE							

Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	
	SUB-STATION	765kV											
		400kV			400/220 kV Hinjewadi (MIDC), District- Pune (WIP) ( Spill over)								
		220kV	220/33kV Mundhale, District-Pune	220/132 kV Lotewadi (NEW) (RE)	220/22 kV Bavdhan Tal: Mulshi (NEW)	220/33 kV Moshi (Safari Park) (NEW)							
			220/33 kV Loni S/S (River view)(NEW)	220/33 kV Marunje / Balewadi, District-Pune	220/33 kV Tathawade (GIS) (YASHADA) (NEW)	220/33 kV Ray Nagar, South Solapur (NEW)							
				220/33kV Watwate	220132//22 kV Knowledge City -Lavale District-Pune								
				220/132/33 kV Waghdari, District-Solapur									
			220kV Talegaon MIDC Phase II										
		132kV			220/22 kV Pride City (Charholi) (NEW)	132/33 kV Wagholi (NEW)							
		110kV											
		100kV											
		765kV											
A-2	ASSOCIATED LINES	400kV			L.ILO on Lonikand I - Koyna Stage IV at Hinjewadi-								
					a)Jejuri-Winjhar section - 103 ckm (WIP) ( Spill over)								
					b) Winjhar-Hinjewadi section -92 ckm (WIP) ( Spill over)								
		220kV	L.ILO on 220kV Lonand-Baramati SC- 5km at Mundhale	L.ILO on both ckts of 220 kV Solapur PG - Narangwadi DC line at 220 kV Waghdari -40km	L.ILO on 220kV Chinchwad - Parvati SC line for 220kV Knowledge park ss -5 km								
				L.ILO on 220kV Chinchwad - Parvati SC line for 220kV Marunje ss -5 km									
				L.ILO on 220kV Lamboti-Pandharpur line 10km at Watwate									
				L.ILO on one ckt of 220kV TalegaonPG-Chakan SS-6 km									
		132kV		L.ILO on both ckt 132kV Waghdari-Tata Renew Solar-5km	L.ILO on Rahatani -Varasgaon -20km @ Knowledge Park/( Lavale phata )								
		110kV											
		100kV											
		765kV											
		400kV			400kV L.ILO - Lonikand-I Jejuri at 765kV Shikrapur PG -30km approx								
		220kV	220KV Solapur (PG) - Bale DC Line-40km (WIP)	220kV TalegaonPG-Chakan DC with HTLS conductor - 6km	220kV Pune-III (ISTS-New) (PG) - Nandedcity 220kV D/C line.-60km (Western Region Network expansion scheme)								
			220 kV D/C line for reorientation of existing line at 220 kV Chinchwad-II -12 ckt kms (Chakan Telco,Parvati, Urse,Hinjewadi I & Flagship)-WIP	Chinchwad Apta for Talegaon (PG) - 36km (WIP)	L.ILO of Chinchwad - Telco at Chakan II - 9km with HPC conductor								
	220 kV DC line from 765 kV Shikrapur PG to 220 kV Khed City - 18 kms	Urse - Chinchwad -20km (WIP)	L.ILO of both ckt of 220 kV Jejuri (M) - Phursungi (M) D/C line- 5km along with HTLS conductor at 765/400/220 kV Pune-III (ISTS-New) (PG) S/s with HTLS conductor (twin zebra equivalent) (Western Region Network expansion scheme)										

Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34		
B	LINK LINES	132kV	220 kV DC line from 765 kV Shikrapur PG to 220 kV Ranjangaon S/s using existing corridor - 10 kms	Chinchwad - Kandalgaon - 28km (WIP)	220kV Karjat -Bhigwan line -25km & 220kV Karjat-Kurumbh line- 30km									
			Reorientation of 220 kV Babhleshwar - Ranjangaon ckt & Lonikand - Ranjangaon Ckt at Khed City - 5 kms	1) LILO of Bale – Osmanabad 220kV S/c line at Solapur – PS (PG) (Western Region Network expansion scheme)										
			220 kV DC line on DC towers from 220 kV Jeur s/s to 400 kV Karajat s/s- 52 kms. (WIP)	2) LILO of Osmanabad – Barshi 220kV S/c line at Solapur PS (PG)(Western Region Network expansion scheme)										
			220 kV DC line on MC towers by making LILO on 220 kV Bhigwan-Kurkumb line at 400 kV Karjat S/S-18 kms. (WIP)	Solapur PS – Jeur 220kV D/c line. (Western Region Network expansion scheme)										
			Zuari - Chettinad - 2km (WIP)	Conversion Chinchwad-Talegaon 100kV tower line to 132kV- 15km	LILO of Indapur -Ujani at Lonideokar- 15km	Conversion of SC to DC towers of 132 kV Phursungi-Kamthadi line (NEW)	132kV Lonikand II to John Deere & Whirlpool SC to DC from Loc No 116 to 207 (New scheme)	Upgradation of 110kV Pandharpur - Puluji - Degaon- into 132kV -55km						
				NCL-Rahatani- 6km	132 kV Walchandnagar - Bawda SCDC line - 35 kms on 132kV Walchandnagar-Indapur line(balance scope )	LILO on 132kV Bekart -Ranjangaon Ckt-2 at 132kV Whirlpool S/Stn (NEW)								
			Conversion of 132 kV Theur - Yavat - Daund SC to DC line (Old line)- 50km-(WIP) ( Spill over)	NCL-Kothrud---Phursungi-18km										
			132kV Kumbhari-Solapur MIDC SCDC (WIP)											
				LILO on 132kV Mahindra forge-Chakn at 220kV Chakan MIDC										
			110kV											
	100kV													
C-1	2nd CIRCUIT STRING	220kV	Tap to LILO Volks Wagon - 3km (to be confirm from ORC) ( Spill over)	220 kV ISMT -Jejuri Tap line	Biltgraphic - Bhigwan-8 km									
				220kV Lamboti-Vairag										
		132kV	Bale -MIDC Solapur- 16km	Puluj-Loknete co-gen (new scheme)	Tap to LILO at 132 kV Bajaj Auto (Chinchwad - Chakan)-5km	2nd ckt stringing of 132 kV Rahatani-Varasgaon line (36 kM) (New)								
				Degaon –Mandrup (GEC)-15km	Jeur-Parewadi	132kV Mandrup-Karajgi								
				Purandwade Tap on Bawada Nira Bhima-Walchandnagar-5km	2nd circuit stringing of 132kV Akkalkot –Karajgi line (NEW)	132 kV Akkalkot -Karajgi								
				Velapur - ShankarNagar-13km	Naldurg - Waghdari- 35km									
			100kV Pudumjee-Talegaon	Malinagar to Velapur- 20km										
110kV														
100kV														
		400kV		HTLS conductor of 400 kV Talegaon (PG) - Chakan (NEW)	HTLS conductor of 400 kV Lonikand - Talegaon (PG) (NEW)									
				HTLS conductor of 400 kV Lonikand - Chakan (NEW)										
			HTLS conductor of 220 kV Lonikand II- Bhosari I(NEW)	HTLS conductor of 220 kV Lonikand II- VSNL (NEW)	220kV Phursungi-Parvati									
			HTLS conductor of 220 kV CHAKAN - BHOSRI (NEW)	HTLS of 220kV VSNL-KHADKI- CENTURY ENKA- BHOSARI-I) (NEW)	HTLS conductor of 220 kV Jejuri - Kondhwa (NEW)									

Sr. No.	Particulars	Vol level	2024 - 25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34
C-2	HIGH AMPICITY CONDUCTOR	220kV	HTLS conductor of 220 kV CHAKAN - CHINCHWAD II (NEW)	HTLS of 220 kV BHOSRI-I & II Line (NEW)	HTLS of 220kV Alephata-Babhleshwar line. (69km) (NEW)							
					HTLS of 220 kV Lamboti-Pandharpur and Lamboti – Karkamb Line (NEW)							
					HTLS of 220kV Talegaon Ambi to PGCIL-I & II line. (NEW)							
		132kV	Conversion of Existing 0.2 ACSR Panther Conductor to HTLS conductor from Loc no-221 to 132kV Whirlpool S/Stn Gantry of 132kV Ranjangaon-Whirlpool line.	HTLS of 132 kV Akkalkot-Chetak – Gokul –South Solapur – Bale line (NEW)	HTLS of 132 kV Malinagar-Bawada Line (NEW)							
132kV Mundhwa-Magarpatta radial ckt 2.5km & Mundhwa-Phursungi ckt via Magarpatta tap -14km			HTLS of 132 kV Pandharpur-Nimboni-Mangalwedha & Pandharpur-Mangalwedha									
		110kV										
		100kV										
C-3	REPLACEMENT OF CONDUCTOR	220kV										
		132kV										
C-4	CONVERSION OF LINE	220kV										
		132kV										
		400kV										
D-1	CREATION OF NEW LEVEL	220kV			Knowledge Park (2X100)MVA 220/132kV							
		132kv										
		33kv										
		765kV										
D-2	ADDITION OF ICT	400kV		400kV Lamboti (3X167)MVA 400/220kV	400kV JEJURI (3X167)MVA 400/220kV							
				400kV Lonikand-I S/S (3X167)MVA 400/220kV (NEW)								
				Lonikand II 1x200MVA 220/132kV ICT								
D-3	REPLACEMENT OF ICT	400kV										
		220kV	Jeur 1X(200-100)MVA 220/132kV	Lonikand II 2X(200-100)MVA 220/132kV								
			Walchandnagar 1X(200-100)MVA 220/132kV	Chakan Phase II 2X(200-100) MVA 220/132kV								
			Pandharpur 1X(200-100)MVA 220/132-100kV	Alephata 2X(200-100)MVA 220/132kV (NEW)								
D-4	TRANSFORMER ADDITION	220kV	Lonikand (1X50)MVA 220/22kV (WIP)	Nanded City(1x50)MVA 220/22kV (WIP)	400kV Chakan (1x50)MVA 220/22kV							
					Shirsuphal (1x25)MVA 220/33kV							
					Jejuri(1x50)MVA 220/22kV (NEW)							
					Century Enka(1x50)MVA 220/22kV (NEW)							
					Ranjangaon(1X50)MVA 220/22kV							
					Pirangut (1X50)MVA 220/22kV	Hinjewadi II (1x50) MVA 220/22kV						
					Bridgestone (1x50) MVA 220/33kV							
					Urse (1X50)MVA 220/22kV							
		132kV		Sanaswadi (1x50)MVA 132/33kV	Rahatani (1x50)MVA 132/22kV							
				Mohol (1x50)MVA 132/33kV (NEW)	Sangola (1x50)MVA 132/33kV (NEW)							
				Manegaon(1x50)MVA 132/33kV (NEW) MSKVY	Someshwarnagar (1x50)MVA 132/33kV (NEW)							













**Special schemes considered for inclusion in STU Plan 2024-25 to 2033-34**

<b>Sr. No.</b>	<b>Name of Scheme</b>	<b>Estimated Cost in Cr.</b>	<b>Approval details</b>	<b>Remarks</b>	<b>Year</b>
1	Design, supply, installation, Testing, & Commissioning of Satation Data Concentrator (SDC)/ Sation RTU/ Gateway with expandable IO modules, MFM and other allied equipment for the Visibility of 132/110/100kV msetcl substation to SLDC & ALDC along with comprehensive Annual maintenace contract for 05 years after 02 years warranty period. BR.No.157/23 Dt.17.10.2022	102.5	BR.No.157/23 Dt.17.10.2022		2024-25
2	Procurement & Installation of CCTV (Centralized Visual Advance Monitoring System CVAMS) at various critical 220 kV S/s & 400 kV Karjat S/s	83.61	B.R. No. 157/15 dtd. 17/10/2022	1) MERC approval received on 13/03/2024. 2) GCC ratified the scheme for inclusion in STU Five Year Plan during 8th GCC meeting held on 04/12/2023.	2024-25
3	Procurement of Remote Airborne Inspection & Scanning System (RAISS) along with all the required accessories for Asset Monitoring.	33.87	B.R. No. 157/13 dtd. 17/10/2022	1) GCC ratified the scheme for inclusion in STU Five Year Plan during 8th GCC meeting held on 04/12/2023. 2) MERC approval awaited.	2024-25
4	Procurement of 04 nos. of Van Mounted Under Ground EHV Cable Fault Locator System to detect & locate the faults in underground cables in	32.95	B.R. No. 162/25 dtd. 08/08/2023	1) GCC ratified the scheme for inclusion in STU Five Year Plan during 8th GCC meeting held on 04/12/2023. 2) MERC approval awaited.	2024-25
6	Procurement of 03 Nos of PTRs & 02 Nos of ICTs as emergency critical spares for Vashi Zone in addition to spare policy	36.15	B.R. No. 163/12 dtd. 21/09/2023	1) Submitted to STU after Prudence Check inputs. Approval awaited	2024-25
7	VSAT	<b>232.23</b>			2024-25
	<b>Total for FY 2024-25</b>	<b>521.31</b>			

5	Procurement of 06 sets of Emergency Restoration System (ERS) comprising of 10 towers each (Suspension Towers - 6 nos. and Angle Towers - 4 nos.) for MSETCL.	176.29	B.R. No. 166/47 dtd. 19/01/2024	1) Submitted to STU for Prudence Check. Approval awaited. 2) Recommended by MTC for submission to GCC for approval during 9th MTC meeting held on 13/03/2024.	2025-26
7	Procurement of 12 Nos of 25MVA 132/11 kV PTRs & 02 Nos 110/11 kV of PTRs as emergency critical spares for all zones of MSETCL	63	B.R. No. 166/24 dtd. 19/01/2024	1) STU has forwarded the DPR after all prudence check inputs. To be submitted to MERC.	2025-26
8	Procurement of balance 04 Nos of ICT & 02 Nos of PTR of various ratings along-with required New Uninhibited High Grade Mineral Insulating Oil, out of earlier sanctioned scheme of procurement of 21 nos. of ICTs & Power Transformers as emergency/critical spares in all zones of MSETCL	74.75	B.R. No. 167/48 dtd. 04/03/2024	1) Submitted to STU after Prudence Check inputs. Approval awaited	2025-26
<b>Total for FY 2025-26</b>		<b>314.04</b>			







		220 kV	---	2 x 250 MVA 220 / 110 kV ICTs at Vikhroli with 220 kV Cable (One ICT work completed and second ICT Work in progress and will be completed in FY 24-25)	Upgradation and Augmentation of existing 110 kV Powai RSS by creation of 220 kV level : 2 X 250 MVA, 220 / 110 / 33 kV ICTs 1 X 125 MVA, 220 / 33 kV Transformer	Upgradation of 110 kV Kalyan RSS to 220 kV with connectivity to 220 kV PAL S/s (MSETCL) (New scheme) 2 X 220 / 110 kV 250 MVA		Interconnection between 220 kV and 110 kV at Waghivali S/s by Installation of 2 x 250 MVA 220 / 110 kV ICTs at Waghivali with EHV cables.	Upgradation of existing 110 kV Parel S/s by creation of 220 kV level : 2 X 250 MVA, 220 / 110 kV ICTs	Upgradation of existing 110 kV Kolshet S/s by creation of 220 kV level : 2 X 250 MVA, 220 / 110 kV ICTs	Upgradation of existing 110 kV Ambarnath S/s creation of 220 kV Level : 2 X 250 MVA, 220 / 110 kV ICTs	Upgradation of 110 kV Mankhurd S/s by creation of 220 kV level 2 X 250 MVA, 220 / 110 kV ICTs
			---	---	---	---	---	Installation of additional 1 X 250 MVA, 220 kV /110 kV/ 33 kV ICT at Saki S/s	---	---	---	---
D-3	ICT - Replacement	400 kV	---	---	---	---	---	---	---	---	---	---
		220 kV	---	2 x 250 MVA, 220 kV / 110 kV / 22 kV ICT 1 & 2 (Salsette) (One ICT being replaced in Non - DPR scheme)	---	---	---	Replacement of 2 x 250 MVA, 220 kV / 110 kV / 22 kV ICT 1 & 2 (Borivali)	---	---	---	---
D-4	Transformers - Addition	220 kV	---	---	---	Upgradation and augmentation of Transformation capacity at Dharavi S/s and Carnac S/s by installation of additional Transformers. 125 MVA, 110 kV / 33 kV / 22 kV Transformer (Dharavi) 125 MVA, 220 kV / 33 kV Transformer (Carnac) (New)	---	---	---	---	---	---
		110 kV	---	---	---	Augmentation of Transformation capacity of Kalyan S/s by installation of 1 X 75 MVA, 220 / 22 kV Transformer along with 220 kV bay extension and installation of 22 kV GIS Bus	---	---	---	---	---	---
D-5	Transformers - Replacement	220 kV	---	---	---	---	---	---	---	---	---	---
		110 kV	---	---	75 MVA, 110 kV / / 33 kV / 22 kV Transformer#2 (Malad) 75 MVA, 110 kV / 33-22 kV Transformer # 3 (Saki)	---	Upgradation of transformation capacity by Replacement of 2 nos, 110/22 kV, 7.5 MVA transformers with 2 nos, 60 MVA Transformer at Panvel S/s	---	---	---	---	---
E-1	Reactor - New	400 kV	---	---	---	2 x 400 kV, 125 MVAR Variable Reactors at Dharavi S/s Part of : Establishing connectivity between North and South Mumbai by 400 kV Phase I : Creation of 400 kV level at existing Dharavi RSS with 400 kV Tata Power Vikhroli - Dharavi S/c line.	---	---	---	---	---	---
		220 kV	---	220 kV, 1 x 125 MVAR (Mahalaxmi) (Work is in progress. Scheme will be completed in FY 24-25)	---	---	---	Installation of 220 kV, 1 x 125 MVAR Reactor at Borivali for Reactive Power compensation	---	---	---	---
			---	220 kV, 1 x 125 MVAR (Trombay) (Work is in progress. Scheme will be completed in FY 24-25)	---	---	---	---	---	---	---	---
		110 kV	---	---	---	---	---	---	---	---	---	---
		33 kV	---	---	---	---	---	---	---	---	---	---
E-2	Reactor-Shifting	400 kV	---	---	---	---	---	---	---	---	---	---
F	Capacitor	33 kV	---	---	---	---	---	---	---	---	---	---
		22 kV	---	---	---	---	---	---	---	---	---	---
		400 kV	---	---	---	Establishing connectivity between North and South Mumbai by 400 kV Phase I : Creation of 400 kV level at existing Dharavi RSS with 400 kV Tata Power Vikhroli - Dharavi S/c line. 400 kV Bays : 10 bays 400 kV Tata Power Vikhroli S/s : 400 kV bays : 07 bays	---	---	---	---	---	---
		220 kV	---	1 no of bay at Mahalaxmi (1 x 125 MVAR Mahalaxmi Reactor) (Work will be completed in FY 24-25)	---	Establishing connectivity between North and South Mumbai by 400 kV Phase I : Creation of 400 kV level at existing Dharavi RSS with 400 kV Tata Power Vikhroli - Dharavi S/c line. 220 kV Bays : 02 nos at Dharavi	Upgradation of 110 kV Vikhroli S/s by creation of 220 kV Voltage level 1) 220 kV bays at Vikhroli : 07 bays	---	---	---	---	---

G	Addition of Bays	220 kV	---	2 no of bay at Trombay (1 x 125 MVAR Trombay Reactor) (Work will be completed in FY 24-25)	---	Upgradation of 110 kV Kalyan RSS to 220 kV with connectivity to 220 kV PAL S/s (MSETCL) (New scheme) 1) 220 kV bays at Kalyan : 07 bays 2) 110 kV bays at Kalyan : 02 bays 3) 220 kV bays at PAL : 02 bays 4) 220 kV bays at Kalwa : 02 bays	---	1 no of bay at Borivali (1 x 125 MVAR Borivali Reactor)	Upgradation of existing 110 kV Parel S/s by creation of 220 kV level : 220 kV bays : 07	Upgradation of existing 110 kV Kolshet S/s by creation of 220 kV level : 220 kV bays : 07	220 kV bays : 02 (Carnac and Backbay S/s) Upgradation / augmentation of South Mumbai 220 kV Transmission Network by installing Additional 220 kV Carnac Backbay cable 6 km (New scheme)	Upgradation of 110 kV Mankhurd S/s by creation of 220 kV level 220 kV Bays : 07
		220 kV	---	---	---	---	---	---	---	---	Upgradation of existing 110 kV Ambernath S/s creation of 220 kV Level : 220 kV bays : 07	---
		110 kV	Consumer funded projects : 2 nos of bays at Malad (Metro 2A) 2 nos of bays at Mahalaxmi (Metro 2A) 5 nos of bays at Mandale (Metro)	2 nos of bays at BKC (Metro) 2 nos of bays at Dharavi (Metro) 2 nos of bays at Powai (Metro) 5 nos of bays at Dahisar (W Rly) 2 nos of bays at Khopoli (C Rly) 5 nos bays at Wadala (Metro) 5 nos of bays at Kanjurmarg (C Rly) 5 nos of bays at IIT Powai (IIT) 7 nos of bays at Amazon S/s	2 nos of bays at Dharavi (Metro) 2 nos of bays at Powai (Metro) 5 nos of bays at Dahisar (W Rly) 2 nos of bays at Khopoli (C Rly) 5 nos bays at Wadala (Metro)	---	---	---	---	Upgradation of existing 110 kV Parel S/s by creation of 220 kV level : 110 kV bays : 02	Upgradation of existing 110 kV Kolshet S/s by creation of 220 kV level : 110 kV bays : 02	Upgradation of existing 110 kV Ambernath S/s creation of 220 kV Level : 110 kV bays : 02
H	Switchgear replacement by GIS	220 kV	---	---	---	Upgradation of 220 kV GIS by replacement with higher 'Breaking Current Rating' and additional bays at Salsette S/s	Upgradation of 220 kV GIS by replacement with higher 'Breaking Current Rating' at Dharavi S/s (New scheme)	---	---	---	---	---
		110 kV	110 kV AIS upgradation by GIS Bays at Parel (Work completed)	---	---	---	---	---	---	---	---	---
			110 kV AIS upgradation by GIS Bays at Dharavi S/S (Work completed)	---	---	---	---	---	---	---	---	---
		33 / 22 kV	MV AIS Switchgear replacement by GIS at Salsette, Chembur, Saki, Ambernath and Borivali (Work completed)	22 kV AIS replacement with bays GIS with additional feeders to DISCOM at Kalayn RSS	Upgradation of 22 kV AIS with GIS along with segregation of back-to-back feeders at Vikhroli RSS	Upgradation of 110 kV at Malad S/s by replacing AIS with GIS	Upgradation of 110 kV GIS at Grant Road with additional bay	Upgradation of MV AIS Switchgear by replacement with GIS at Salsette and Borivali S/s (New scheme)	110 kV AIS upgradation by GIS at Borivali S/s	110 kV AIS upgradation by GIS at Trombay S/s (New scheme)	110 kV AIS upgradation by GIS at Salsette S/s (New scheme)	110 kV AIS upgradation by GIS at Kalyan S/s (New scheme)
I	Miscellaneous	---	Replacement of Transmission Line Towers in Vashi Waghvali Creek area : 1. 110 kV Waghivali - Mankhurd line : Replacement of towers, conductors and foundation from 77 nos to 83 nos and tower nos 120 to 122 lying in Vashi & Waghivali Creek. 2. 110 kV Waghivali - Chembur line : Replacement of towers, conductors & foundations of Tower nos 79 to 85 and tower nos 126 to 128 lying in Vashi & Waghivali Creek.	Centralized Grid Connected Battery Energy Storage System (BESS) of 200 MW at Trombay S/s for Grid Support in Mumbai Transmission System	Installation of Static Synchronous Compensator (STATCOM) for better voltage regulation at Mankhurd S/s, Trombay S/s, Parel S/s, Dharavi S/s and	---	---	Upgradation of existing unified SCADA	---	---	---	

AEML-T & AEMIL STU 10 year Plan at Glance sheet FY 2024-25 2032-33

			2024-25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34
A1	EHV Substations	220kV	220/33 kV GIS EHV S/s at BKC	220/33 kV GIS EHV S/S at Chandivali	220/33 kV GIS EHV S/S at Kandivali	220/33kV GIS EHV S/S at Khardanda	220/33 kV GIS EHV S/S at Malad (E)	220kV Kashi Village EHV S/s				
					220/33 kV GIS EHV S/S at Dahisar	220kV Scheme at Tilak Nagar/ Sidharth Nagar Estimated	220/33kV GIS EHV S/S at Airport Estimated Cost	220 kV Tagor Nagar GIS EHV S/s				
					220KV Switching S/s at Ghodbunder (Augmentation of Borivali-Ghodbunder-Bolsar LILO line)	220kV Nahar EHV Station		220kV Vazra Naka (Don Bosco) EHV S/s				
					220kV Scheme at Uttan/ Rai Village(New)							
A2	Cost (Cr.)	± 320 kV										
		400kV										
		220kV	220KV Chembur BKC EHV S/s D/C Line (U/G cable) - 24 Ckt. Km	220 kV LILO of TPC Salsette – Saki Line (at 220kV Chandivali EHV Scheme) -1 Ckt. Km	LILO of 220kV Bolsar-Versova Line at Kandivali -8.4 Ckt. Km	220 kV LILO of Aarey- BKC line at Khardanda - 7 Ckt. Km	LILO of 220kV Aarey - TPC Borivali OH line at Malad - 2 Ckt. Km	220kV Ghodbunder LILO S/s - Kashi Village EHV S/s D/C Line (U/G cable) - 1 Ckt. Km				
					220 KV Ghodbunder - Dahisar D/C Line (U/G cable) - 13 Ckt. Km	220kV LILO of TPC Trombay –Salsett Line at Tilak Nagar / Sidhartha Nagar EHV S/s – 4 Ckt Km	220 kV LILO of Aarey- BKC line at Airport – 4 Ckt. Kms	220kV Trombay - Salsette LILO at Tagore Nagar - 1 Ckt. Km				
B	Link Lines	220kV			220 KV LILO of AEMIL Dahanu - Versova line at Uttan – 8 Ckt. Km	LILO of 220kV Aarey - Chandivali line at Nahar EHV Station - 9 Ckt. Km		LILO of MSETCL Borivali- Gorai at Vazra Naka EHV S/s - 1 Ckt. Km				
						220kV D/C cable Connectivity Between Dahisar EHV Station – 220kV AEML-T Borivali EHV S/S - 12 Ckt. Km route	220 kV D/C cable connectivity Between 220 kV AEML-T BKC and 220 kV AEML-T Aarey - 35 Ckt. km					
C	Transformers – Addition	220kV			03rd. 220/33 kV, 125 MVA Transformer at BKC EHV S/s	3rd Transformer at Chandivali	03rd. 220/33 kV, 125 MVA Transformer at Kandivali EHV S/s	03rd. 220/33 kV, 125 MVA Transformer at Khardanda EHV S/s	03rd. 220/33 kV, 125 MVA Transformer at Malad EHV S/s	3rd Transformer at Tagor Nagar EHV S/s		
						220kV S/C from AEML Aarey to AEML Chandivali and S/C from AEML Aarey to TPC Saki- 6.6 Ckt. Kms	220kV Cable system between TPC Sahar to AEML Airport- 3 Ckt. Km	03rd. 220/33 kV, 125 MVA Transformer at Dahisar EHV S/s	3rd Transformer Nahar EHV S/s	3rd Transformer at Airport	3rd Transformer at Kashi Village EHV S/s	
D	Reactor – Installation	220kV		100-120 MVAR Reactor at Chembur EHV S/s (New)								
		33 kV				33 kV Reactors at 220 kV/33 AEML-T kV EHV Station						
E	Additional Schemes	220kV & 33kV	220kV AIS to GIS Conversion at Aarey EHV S/s		220kV AIS to GIS Conversion at Versova EHV S/s	Installation of 250 MW BESS at Dahanu						
					220kV AIS to GIS Conversion at Ghodbunder EHV S/s	33kV AIS to GIS Conversion at Aarey (2 Boards) VSV (1 Board) & GBR (1 Board)						
F	C4-HTLS	220kV				Line Augmentation with HTLS/ Twin Conductors						
<b>AEMIL 1000 MW HVDC (VSC based) Scheme</b>												
A1	EHV Substations	±320 kV		1000 MW HVDC Terminal Stations at Kudos & Aarey (WIP)								
A2	Associated Lines			HVDC link between Kudos-Aarey -80 KMS route-(WIP)				Upgradation of 1000MW HVDC (VSC based) Kudos to Aarey Link.				

New Corridor Schemes					Annexure-E					
Sr. No.	Phase	Voltage Level	Substation / Line	Tentative interconnection	Type	ICT MVA	Line Length	Line Reactor (MVA)	Bus Reactor	Year
1	1	400 kV	400kV Line	400kV D/C line from 400kV Jejuri (existing) to 400kV Hinjewadi (existing) <b>(Note: Reorientation/Bypassing of 400 kV Koyna - Jejuri &amp; Lonikand - Jejuri line to form 400 kV Koyna - Lonikand line and utilisation 400 kV Bays at Jejuri S/s)</b> (2000MW Capacity each)	Demand HotSpot		120	250		2025-26
2	1	765 kV	765/400 kV Pune (East)	LILO of both circuit of 765kV Aurangabad (PG) (Existing) - Solapur(PG) (Existing) D/C at 765kV Pune (East)	Demand HotSpot	3000	60		240 MVA Bus Reactor @ 765kV level	2027-28
				765kV D/C line from Pune (East) (New) to 765kV Pune- III GIS (Proposed)			300			
				2x1500MVA, 765/400kV ICT			40			
				Connecting 765kV Pune (East) (New) with 400kV Karjat (existing) through 400kV Line D/C			200			
				400kV D/C line from 765/400 kV Pune (East) (New) to 400 kV Lonikand-I (existing)						
			Bays @ 400kV Karjat (2nos.), 400kV Lonikand-I (2nos.)							
3	1	400 kV	400/220 kV Saswad	400kV D/C line from 400kV Saswad (New) to 765/400kV Pune-III (Proposed)	Demand HotSpot	1000	100		125 MVA Bus Reactor @ 400kV level	2026-27
				LILO on 400 kV Lonikand - Koyna at 400 kV Saswad (New)			40			
				2x500MVA , 400/220kV ICT			35			
				220kV Saswad (New) - Theur (existing) D/C			30			
				LILO on 220kV Jejuri (existing) - Phursungi (existing) D/C line at 220kV Saswad (New)			20			
			220kV Saswad (New) - Nanded City (existing) D/C Bays @ 220kV Theur (2nos.)							
4	1	765 kV	765/400/220 kV Mahape	765 kV D/C line from 765kV Mahape (New) to 765kV Padghe-(PG) (existing)	Data Center	6000	120		240 MVA Bus Reactor @ 765kV level	PADHGE LINE: 2026-27 APTA LINE: 2028-29
				4x1500MVA, 765/400kV ICT						
				400 kV connectivity to Datacenter Consumers			2000			
				4x500MVA, 400/220kV ICT						
				220 kV connectivity to Datacenter Consumers						
5	1	400 kV	400/132 kV Jalna	LILO OF A'BAD-II (THAPTI TANDA) (existing) - A'BAD-III (EKTUNI) (existing) D/C AT 400kV JALNA (New)	Demand HotSpot	1500	160		125 MVA Bus Reactor @ 400kV level	2026-27
				3x300MVA , 400/132kV ICT						
				132kV M/C Lines from 400/132kV Jalna (New) to 132kV Jalna MIDC (existing) with quad conductor			50			
				LILO on 132kV Ambad (Existing) - Partur (Existing) line at 400/132kV Jalna (New)			15			
				LILO on 132kV Ghansawangi (Existing)- Partur (Existing) line at 400/132kV Jalna (New)			15			
			132kV connectivity to EHV consumers							
6	1	765 kV	765/400kV Nashik	765 kV D/C line from 765kV Nashik (New) to 765kV Boisar-II (PG) (Proposed)	Demand HotSpot	3000	300		240 MVA Bus Reactor @ 765kV level	2027-28
				765 kV D/C line from 765kV Nashik (New) to 765kV Dhule (BDTCL) (existing)			320			
				2x1500MVA, 765/400kV ICT						
				2x500MVA , 400/220kV ICT			1000			
				220 kV D/C line from 400kV Pimpalgaon (Proposed) to 220kV Girnare / Trembakeshwar (New) (400kV Line operated at 220kV)			50			
				220 kV D/C line from 220kV Girnare / Trembakeshwar (New) to 220 kV Raymond (existing) or upgradation of 132kV Jindal (existing) (400kV Line operated at 220kV)			30			
				2x100MVA, 220/132kV ICT at 220kV Girnare / Trembakeshwar (New)			100			
				132kV D/C Lines from 220/132kV Girnare / Trembakeshwar (New) to 132kV Mhasrul (existing) or LILO of existing 132kV Lines of Nashik 132kV RingMain			20			
			220 kV line from 765/400/220kV Nashik (New) to 220kV Sinner/Khapparale (New) (400kV Line operated at 220kV)							

				220 kV D/C line from 220kV Raymond to 220kV Sinner/Khaparale (New) for 220kV RingMain (400kV Line operated at 220kV)		50				
				220kV D/C Line from 765/400/220kV Nashik to 220kV Nashik (OCR) (400kV Line operated at 220kV)		50				
				2x200MVA, 220/132kV ICT at 220kV Sinner/Khaparale (New)		200				
				LILO on 132kV Sangamner - Khaparale at 220kV Sinner/Khaparale (New)		10				
				LILO on 132kV Akole (existing) - Khaparale (existing) at 220kV Sinner/Khaparale (New)		10				
				Bays @ 765 kV Dhule (BDTCL) (2nos.), 400kV Pimpalgaon (2nos.), 400kV Malegaon (2nos.), 220kV Raynond (2nos.)						
7	1	400 kV	400/220/132 kV Washi	400kV D/C line from 400kV Washi (New) to 765/400kV Pune (East) (New)	RE Evacuation (~2000MW, appl. closed)	300		125 MVAR Bus Reactor @ 400kV level	2026-27 (Matching with RE)	
				2x500MVA, 400/220kV ICT		1000				
				220kV lines to Solar Generators						
				220kV D/C Line from 400/220/132kV Washi (New) to 220kV Manjarsumba (existing)		35				
				220kV D/C Line from 400/220/132kV Washi (New) to 220kV Paranda (existing)		40				
				2x300MVA, 400/132kV ICT		600				
				132kV D/C line from 400/220/132 kV Washi (New) to 132kV Kallam (existing)		10				
				132kV lines to Solar Generators Bays @ 220kV Manjarsumba (2nos.), 220 kV Paranda (2nos.), 132kV Kallam (2nos.)						
8	1	400 kV	400/220kV Wagdari	400kV D/C line from 400kV Wagdari (New) to 400kV Solapur Pooling	RE Evacuation (~1000MW)	140		125 MVAR Bus Reactor @ 400kV level	2026-27 (Matching with RE)	
				3x500MVA, 400/220kV ICT		1500				
				220kV D/C line from 400/220kV Wagdari to 220/132kV Wagdari (proposed) 220kV lines from Solar Generators		40				
9	1	400 kV	400/220 kV Umred	LILO on Both circuit of 400kV Tiroda (Adani) (existing) - Warora (MSETCL) Existing D/C line at 400/220/132kV Umred (New)	Demand HotSpot	28			2026-27	
				2x500MVA, 400/220kV ICT		1000				
				220kV D/C line from 400/220/132kV Umred (New) to 220kV Buttibori (existing)		90				
				LILO on Both circuit of 220kV Umred (existing) - Nagbhid (proposed) D/C line at 400/220/132kV Umred (New)		8				
				2x200MVA, 220/132kV ICT at 400/220kV Umred (New)		400				
				132kV S/C line from 132kV Pennar (existing Consumer) to 400/220/132kV Umred (New)		20				
				132kV S/C line from 132kV DCL (existing Consumer) to 400/220/132kV Umred (New)		20				
				132kV S/C line from 132kV Kolar (existing) to 400/220/132kV Umred (New)		30				
				132kV S/C line from 132kV Ambhora (existing) to 400/220/132kV Umred (New)	20					
10	1	400 kV	400/220 kV Sakoli	LILO on Both circuit of 400kV Tiroda (Adani) (existing) - Warora (MSETCL) Existing D/C line at 400/220/132kV Sakoli (New)	Demand HotSpot	4			2026-27	
				2x500MVA, 400/220kV ICT		1000				
				220kV D/C line from 400/220/132kV Sakoli (New) to 220kV Bhandara (existing)		80				
				2x200MVA, 220/132kV ICT at 400/220kV Sakoli (New)		400				
				132kV D/C line from 132kV Deori (proposed) to 400/220/132kV Sakoli (New)		100				
				132kV D/C line from 132kV Sakoli (existing) to 400/220/132kV Sakoli (New)		4				
				132kV S/C line from 132kV Sakoli (existing) to 132kV MorgaonArjuni (existing)		50				
				132kV S/C line from 132kV MorgaonArjuni (existing) to 132kV Bhamhapuri (existing)		40				
				<b>TOTAL</b>	<b>23700</b>	<b>3254</b>				

Sr. No.	Phase	Voltage Level	Substation / Line	Tentative interconnection	Type	ICT MVA	Line Length	Line Reactor (MVAR)	Bus Reactor	Completion of Project
1	2	765 kV	765kV Pune (WEST)	765kV LILO on One circuit of 765kV Neral (PG) (proposed) - Pune-III (PG) (proposed) - at 765kV Pune (WEST) (New)	Data Centre		30	240 MVAR Bus Reactor @ 765		2027-28 (Matching with DC)
				2x1500MVA, 765/400kV ICT		3000				
				400 kV D/C line from 765kV Pune-(WEST) (New) to 400kV Hinjewadi (Proposed)			60			

				400 kV connectivity to Datacenter Consumers Bays @ 400kV Hinjewadi (2nos.)						
2	2	765 kV	765/400 kV Balsane-II	765kV D/C line from 765kV Dhule (BDTCL) (existing) to 765/400kV Balsane - II (New)	RE Evacuation (2600MW: 3 Appl.)		160		240 MVar Bus Reactor @ 765kV level	2027-28
				2x1500MVA, 765/400kV ICT		3000				
				400kV D/C lines from 765/400kV Balsane-II (New) to 400kV Balsane (proposed)			40			
3	2	765 kV	765/400/220 kV Alkud-II / Jath	765kV D/C line from 765kV Alkud-II / Jath (New) to 765kV Pune-III (PG) (Proposed) along with Line Reactor at both ends	RE Evacuation (~2000MW)		440		240 MVar Bus Reactor @ 765kV level	2028-29
				2x1500MVA, 765/400kV ICT		3000				
				400 kV D/C line from Alkud (Existing) to 765/400 kV Jath (New)			70			
				2x500MVA, 400/220kV ICT		1000				
				LILO on 220 kV Jath - Mhaishal Line at 765/400/220 kV Alkud-II / Jath			20			
				Bays @ 400kV (Alkud) (2nos.)						
				220kV lines from Solar Generators						
4	2	765 kV	765/400 kV Kandalgaon	765 kV 2 x D/C line from 765kV Kandalgaon (New) to 765kV Pune-III (proposed)	Pooling Station / PSP Evacuation		400		240 MVar Bus Reactor @ 765	2028-29
				LILO on Both circuits of 400kV Dabhol - Nagothane D/C line at 765/400 kV Kandalgaon (New)			60			
				3x1500MVA, 765/400kV ICT		4500				
				2x500MVA, 400/220kV ICT		1000				
				Connectivity to PSPs						
5	2	HVDC	765/400/220 kV Dolvi	765 kV 2x D/C line from 765kV Kandalgaon (New) to 765kV Dolvi (New)	Demand HotSpot		260			2028-29 (AC) & 2029-30 (DC)
				3x1500MVA, 765/400kV ICT		4500				
				LILO of One circuit of 400 kV Padghe-Nagothane D/C line (WIP)			40			
				2x500MVA, 400/220kV ICT		1000				
				LILO on 220kV Apta - Uran D/C line at Dolvi			30			
				220kV D/C line from 220kV Dolvi to 220kV Wadkhal			2			
				Bays @ 220kV Wadkhal ( 2nos.)						
6	2	765 kV	765kV Apta	765 kV D/C line from 765kV Apta (New) to 765kV Dolvi(New)	Demand HotSpot		160		240 MVar Bus Reactor @ 765	2028-29
				765kV Mahape (New) - Apta (New) D/c			80			
				3x1500MVA, 765/400kV ICT		4500				
				Connectivity to EHV consumers						
7	3	400 kV	400 kV Mazgaon	400kV S/C UG Cable from 400kV Mazgaon (New) to Mahalaxmi (New)	Demand HotSpot (HVDC Converter Station)		9		125 MVar Bus Reactor @ 400	2029-30
				400kV Mazgaon (New) - Dharavi (New) S/c UG Cable			12			
				3x500MVA, 400/220kV ICT		1500				
				LILO on 220kV Seori-Carnac 3xS/c at Mazgaon			15			
				Bays @ 400kV ( 2nos.) at Mahalaxmi, 400kV ( 2nos.) at Dharavi						
8	3	400 kV	400 kV Trombay	400kV Trombay(New) - Vikhroli D/c	Demand HotSpot (HVDC Converter Station)		15		125 MVar Bus Reactor @ 400	2029-30
				3x500MVA, 400/220kV ICT		1500				
				Upgradation of 220 kV Trombay(existing)						
9	3	400 kV	400 kV Mahalaxmi	400kV S/C line from 400kV Mahalaxmi (New) to 400kV Dharavi (New)	Demand HotSpot		8		125 MVar Bus Reactor @ 400	2029-30
				2x500MVA, 400/220kV ICT		1000				
				Upgradation of 220 kV Mahalaxmi(existing)						
10	3	400 kV	400 kV Dharavi		Demand HotSpot				125 MVar Bus Reactor @ 400	2029-30

			400kV S/C line from 400kV Dharavi (New) to 400kV Vikhroli (New)		10			
			3x500MVA, 400/220kV ICT		1500			
			Upgradation of 220 kV Dharavi(existing)					
11	2	400 kV	400/220 kV Ambernath	LILO on One circuit of 400kV Padghe - Nagothane D/C line at 400kV Ambernath	Demand HotSpot	40	125 MVAR Bus Reactor @ 400	2028-29 (Matching with Neral/Kalamamb(ISTS))
				3x500MVA, 400/220kV ICT		1500		
				220kV Lines reorientation at 220kV Ambernath		20		
12	2	400 kV	400/220 kV Hingoli West	400kV D/C line from 400kV Hingoli West (New) to 400kV Jalna (New)	RE Evacuation	320	125 MVAR Bus Reactor @ 400	2028-29 (Matching with RE)
				220kV D/C line from 220kV Hingoli west to 220kV Bhokar		80		
				220kV Hingoli west to Hingoli D/C Interconnection		20		
				Bays @ 220kV (2nos. each) at Bhokar & Hingoli				
				2x500MVA, 400/220kV ICT		1000		
13	2	400 kV	400/220 kV Latur / Tuljapur / (Belkund Sindhal)	400kV D/C line from 400kV Latur/Tuljapur to 400 kV Solapur PS	RE Evacuation	20	125 MVAR Bus Reactor @ 400	2028-29 (Matching with RE)
				220kV D/C line from 400/220 kV Latur/Tuljapur to Jalkot		300		
				220kV D/C line from 400/220 kV Latur/Tuljapur to Tuljapur		20		
				220kV lines to Solar Generators		10		
				2x500MVA, 400/220kV ICT		1000		
				Bays @ 220kV (2nos. each) at Nilanga & Tuljapur				
14	2	400 kV	400/220 kV Yavatmal	400kV D/C line from 400kV Hingoli West (New) to 400kV Yavatmal (New)	RE Evacuation	360	125 MVAR Bus Reactor @ 400	2028-29 (Matching with RE)
				2x500MVA, 400/220kV ICT		1000		
				LILO on 220kV Yavatmal - Ghatodi line at 400/220kV Yavatmal (New)		30		
				220kV lines to Solar Generators				
15	2	HVDC	HVDC Dolvi	1500MW HVDC under sea cable from 765/400 kV Dolvi to 400kV Mazgaon (New)	Demand HotSpot	100		2029-30
				1500MW HVDC under sea cable from 765/400 kV Dolvi to 400kV Trombay		80		
				HVDC Terminal Station		3000		
16	3	765 kV	765 kV Dahanu (Vadhwan)	765 kV D/C Line from 765kV Dahanu(New) to 765/400kV Boisar-II(New)	Green Hydrogen	20	240 MVAR Bus Reactor @ 765	2029-30
				3x1500MVA, 765/400kV ICT		4500		
17	3	765 kV	765 kV Revdanda	765kV D/C line from 765 kV Apta(New) to 765kV Revdanda Port(New)	Green Hydrogen	20	240 MVAR Bus Reactor @ 765	2029-30
				3x1500MVA, 765/400kV ICT		4500		
18	3	765 kV	765 kV JNPT	765kV D/C line from 765kV JNPT Port (New) to 765 kV Apta(New)	Green Hydrogen	20	240 MVAR Bus Reactor @ 765	2029-30
				3x1500MVA, 765/400kV ICT		4500		
19	2	HVDC	HVDC Velgaon	HVDC Terminal station at Velgaon	Demand HotSpot	1500		2029-30
				750MW HVDC line from 400 kV Velgaon to Ghodbunder		100		
				HVDC Multi-terminal Station at Ghodbunder		750		
				750MW HVDC Line from Ghodbunder to 400kV Versova		120		
20	3	400 kV	400 kV Versova	400kV D/C line from 400kV Versova (New) to 400kV Khardanda (New)	Demand HotSpot	16	125 MVAR Bus Reactor @ 400	2029-30
				2x500MVA, 400/220kV ICT		1000		
				Upgradation of 220 kV Versova (existing)				
21	3	400 kV	400 kV Khardanda		Demand HotSpot		125 MVAR Bus Reactor @ 400	2029-30
				2x500MVA, 400/220kV ICT		1000		
				Upgradation of 220 kV Khardanda (Proposed)				
22	3	400 kV	400 kV Aarey	400kV D/C line from 400kV Aarey (New) to 400kV Chandivali (New)	Demand HotSpot	8	125 MVAR Bus Reactor @ 400	2029-30
				2x500MVA, 400/220kV ICT		1000		
				Upgradation of 220 kV Aarey (existing)				
23	3	400 kV	400 kV Chandivali	2x500MVA, 400/220kV ICT	Demand HotSpot	1000	125 MVAR Bus Reactor @ 400	2029-30
				Upgradation of 220 kV Chandivali (Proposed)				
				<b>Total</b>		<b>58250</b>	<b>3625</b>	