



MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

Name of office : EHV O & M Division, MSETCL, Karad.
Office Address : Administrative Building, Ground Floor, Vijaynagar, Karad-415114, Dist: Satara.
Contact No. : Tel. (O): 02164-255199, (P):02164-255047, (R):02164-255444Fax:02164-255047
Email ID : ee3110@mahatransco.in

Ref No: EE/EHV (O&M) DN/KRD/T/ No. 749

Date: 09.08.2023.

TO WHOM SO EVER IT MAY CONCERN

Please find attached herewith a detail schedule **Supply Digital Earth Tester & Digital Multi-meter at various S/Stn. under EHV O&M Dn. Karad.**

All interested & experienced bidders are requested to submit their best lowest budgetary offer as per the schedule 'A' along with applicable rate of GST for materials attached, same up to **Dtd. 16.08.2023** by e-mail at ee3110@mahatransco.in.

Please note that this budgetary offer is for estimation purpose only.

Sd/-
(Santosh G. Bide)
Executive Engineer,
EHV (O&M) Division Karad

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

EHV O&M DIVISION KARAD.

CIN No: U40109MH2005SGC153646

SCHEDULE 'A'

Sub.-: Supply of Digital Earth Tester & Digital Multi-meter at various S/Stn. under EHV O&M Dn. Karad.

Sr. No.	Particulars	Unit	Qty.	Rate Per unit Rs.
	Supply Portion			
01	Supply of Digital Earth Tester (Make- Megger/ Motwane/ Rishabh/ Fluke) having specification :- 1. Earth Resistance: Range 0.01 Ohm to 19.99 Ohm. 2. Test Current: 20 Ohm range, 10mA AC RMS approx. 3. Resolution: 0.01 Ohm. 4. Earth Voltage: 0-200VAC, Resolution 0.1V. 5. Accuracy: 2% of range. 6. Test Frequency: 128 Hz +/-0.5Hz	No.	01	
02	Supply of Digital Multi-Meter (Make- Megger/ Motwane/ Rishabh/ Fluke) having specification :- 1. Voltage Range: A. DC- 1000Volts; B. AC- 1000 Volts 2. Voltage Accuracy: A. DC- +/- 0.5% + 3digit, B. AC - +/- 1 % + 3digit. 3. Current Range: A. DC- 10 Amp. B. AC- 10 Amp. 4. Current Accuracy: A. DC- +/- 1.5% + 3digit, B. AC - +/- 1.5 % + 3digit. 5. Resistance range: 40 M Ohm 6. Resistance Accuracy: +/- 1.5% + 3digit 7. Capacitance: 1000 micro F. 8. Capacitance Accuracy: +/- 5% + 5digit	No.	01	

Note: - Taxes should be quoted distinctly if any.

Sd/-
(Santosh G. Bide)
Executive Engineer,
EHV (O&M) Division, Karad.