

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD
CIN No.:- U40109MH2005SGC153646

Office of: -

The Executive Engineer, Protection Automation & Communication (PAC)
Division, MSETCL, Nanded
Address : Vidyut Bhavan, Sathe Chowk, New Mondha, Nanded-431601
Contact: 02462-286903(P), 286906(O) (Fax), 267994
Email: eenandedt@gmail.com, ee2520@mahatransco.in

No. EE (T)/EHV/ Tech/ 259

DATE- 08.09.2023

E-Enquiry

Subject: - E-Enquiry for supply of 5 KV Digital insulation tester & Clamp meter, for Testing Units under EHV PAC Division, Nanded.

Dear Sir,

Sealed and super scribed quotations are invited by undersigned for 'for supply of 5 KV Digital insulation tester & Clamp meter, for Units under EHV PAC Division, Nanded. as per detailed schedule 'A' enclosed herewith subject to the following terms and conditions, from date **09.09.2023** so as to reach this office up to date **15.09.2023** up to **17:00** hrs.

TERMS AND CONDITIONS: -

The Rate shall be quoted on firm quotation basis as per mentioned in schedule attached.

The quotation should be sent under sealed cover duly super scribed as Quotation for " Supply of of 5 KV Digital insulation tester & Clamp meter, for testing Units under EHV PAC Division, Nanded.

1. (Enquiry No. be quoted).
2. The price quoted by you in your quotation for supply of the material shall be on firm quotation basis for Delivery at PAC Dn Nanded inclusive of packing and forwarding, insurance & transportation etc.
3. Your quotation should reach this office on or before **Dt.15.09.2023 up to 17:00Hrs** and the same will be opened on the same day, if possible.
4. Quotation received after due date will not be considered. This office is not responsible for any postal delay.
5. Documents required: -The rate quoted must be accompanied with the following documents duly attested & signed by the Agency.
 - A. Copy of valid Shop act/Udyog Aadhar /Udyam
 - B. Copy of Valid Proof of registration under GST.
 - C. Copy of Pan card
 - D. Manufacturer / Authorized dealer/ Dealer/ sub dealer/ Distributor Certificate/Previous Experience in supply of Similar material in MSETCL

6. Income tax, labour cess & any other applicable Taxes will be recovered as per prevailing rules.
7. Quantity: - Quantity shown in "Schedule." may vary subjected to order value limited to Rs. 703255.22/- (including of all taxes).
8. Necessary test certificates must accompany with the consignment. If necessary, the material will be tested before / after delivery to ensure that it conforms to the specifications. If the same is not conforming, then the whole lot will be liable for rejection.
9. Payment: - No advance payment shall be made in any case. 100% payment will be made after receipt of bills in triplicate (Indicating PAN No. GST Reg. No.) to this office for arranging payment. No part payment will be made.
10. The undersigned reserves the right to place order either partly or fully or to reject any or all the quotations without assigning any reasons whatsoever.
11. Please quote your PAN & GST No. in the quotation.
12. Delivery Period: - The material shall be supplied within 30 days from the date of receipt of this office order otherwise penalty *rci*.1% per week subject to max,10% of the order amount will be levied at the discretion of the Competent Authority.
13. Sample: -You will have to take approval for supplied material before dispatch. The Executive Engineer PAC Division Nanded or his representative will approve the sample from supplied material as per Schedule "A" if not found,undersigned has right to reject complete material without assigning any reason.Catalogue of the Model, Test Certificate to be attached.
14. Material: It is mandatory to supply quality material. If any defect observed in the material supplied by you, the same shall be replaced by you free of cost & without delay.
15. Guarantee for Quality of Material : There must be Guarantee for satisfactory performance of the material for period of atleast **12** months from the date of receipt of material at the desired location
16. Security Deposit: - Security deposit i.e.10% of order value to be paid before supply of material in terms of cash/DD/FDR of Nationalized bank/scheduled bank in favour of the Executive Engineer. EHV (O&M) Div. Nanded from the date of issue of order.
17. All the MSETCL's general terms & conditions for purchase will be binding on you.
18. Order will be placed to the agency who has quoted combined lowest rate.
19. **Agreement Bond**: - You will have to sign an agreement with MSETCL regarding abiding with all the terms and conditions of this order on a non-Judicial stamp paper of Rs. 500/-. The matter to be printed on the stamp paper will be provided to you by this office. The cost of stamp paper will have to be borne by you.

Thanking you.

Encl.:- "Schedule A"

Yours faithfully.

Sd/-
Executive Engineer
EHV PAC Division Nanded.

Copy to:-1. The Manager. (F&A). EHV (O&M) Division Nanded.

SCHEDULE "A"

Scope of work: Supply of 5 KV Digital insulation tester & Clamp meter, for Testing Units under EHV PAC Division, Nanded.

Sr. No.	Particular of Work	Unit	Qty.	Unit Rate in Rs	Total
1	Supply of Diagnostic insulation tester as per following specifications Insulation Resistance up to 1TΩ, Short-Circuit Current up to 1.5mA, Wide Test Voltage from 250V to 5000V, Diagnosis Function of PI and DAR, Newly-designed alligator clip, tough hard case, Filter function which reduces noise interference for obtaining stable measurement, Large display with Bar Graph indication and backlight, Live voltage warning, Safety standard IEC 61010-1 CAT IV 300V / CAT III 600V, Accessories having Line probe: >=3m, Earth cord: >=3m, Guard cord: >=3m, Hook type prod, Voltage measurement accuracy - AC: 30-600V (50-60Hz), Voltage Measurement Accuracy- DC: ±30 - ±600V, ±2%rdg±3dgt, Internal battery or External power supply for charging. Preferably Make:- Megger/Kyoritsu/Fluke.	Nos.	3		
2	<u>Digital Clamp Meter</u> Specification:-AC. A Ranges -0-400mA-4A-100A Jaw Dia:- Max 40 mm (With firm contact of Transformer jaws.).Accuracy :-Upto 2 % for all ranges. Resolution:-Up to 1mA to 10mA on different ranges. LCD Display.3-1/2 digit liquid Crystal display. Safety Standarad:-IEC 61010-1,IEC 61010-2-032 CAT III Preferably Make:- Fluke/Megger/Kyoritsu/Multi Japan	Nos.	4		
				Sub Total I	
				Add GST@18% on Sub-Total I	
				Grand Total	

Amount In Words:

Sd/-
Executive Engineer
EHV PAC Division Nanded.