
 <p>MAHATRANSCO Maharashtra State Electricity Transmission Co. Ltd.</p>	<p>Name of Office: The Executive Engineer , 400KV RS (O&M) Dn. Karad. Office Address : Administrative Building, Ground Floor, Vijaynagar, Post – Supane, Tal – Karad Dist – Satara, Pin No. 415114 Contact No. : 02164-255182 E-mail ID : ee3130@mahatransco.in</p>	
--	---	---

EE/400KV RS O&M/Dn/KRD/T/No.633

Date:21.09.2023

TO WHOM SO EVER IT MAY CONCERN

BUDGETARY OFFER

All interested & experienced bidders are requested to submit their best lowest budgetary offer at Office of The Executive Engineer 400KV RS (O&M) Dn. Karad Administrative Building, Ground Floor, Vijaynagar, Post – Supane, Tal – Karad Dist – Satara, Pin No. 415114 or e-mail ID ee3130@mahatransco.in for **Supply of 02 Nos of 36KV PT & 03 Nos of 36KV Neutral CT of 3x105MVA ICT units ICT-I & II at 400KV RS Karad.**

Please submit the same up to **Dtd.29.09.2023**. Taxes should be quoted distinctly if any.

Note: The bidder procure the material / equipment from approved vendor of MSETCL for said equipment. The list of vendor is available at www.mahatransco.in

Please note that this budgetary offer is for estimation purpose only.

Contact no. 9767104586 Dy.Executive Engineer (Mahendra Pihulkar)

Sd/

(C.L.Bharamgunde)
Executive Engineer
400KV RS (O&M)Dn.Karad

Encl.:- Schedule 'A'.

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.
400 KV R.S.(O&M) DN., KARAD**

SCHEDULE 'A'

Sub.:- Supply of 02 Nos of 36KV PT & 03 Nos of 36KV Neutral CT of 3x105MVA ICT units ICT-I & II at 400KV RS Karad.

Sr. no.	Description of material	SAP Material No.	HSN code	Unit	Qty.	MSETCL unit rate including all.
A	SUPPLY PORTION					
1	36kV Neutral CT 1000/1A 1C 600VA 36kV 1000/1 A 1 Core Min. Knee Point Voltage-600V, Max. RCT at 75 °C <=5Ω,Max.I Ext. at Min.Vk <= 50 mA Neutral Current Transformer	500024890	85042100	EA	03	
2	36kV PT (33kV/√3)/(110V/√3) 3C c Rated V.F.-1.2 Continuous & 1.9 for 8 Hrs, Metering core-Burden -50 VA & Class of Accuracy-0.5, Protection core-Burden -100 VA & Class of Accuracy-3P, Min Total Creepage Dist- 900 mm	500000054	85042100	EA	02	

Note :- Taxes should be quoted distinctly if any.

(C.L.Bharamgunde)
Executive Engineer
400KV RS (O&M)Dn.Karad