

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.



Name of office: 400KV RS Division, MSETCL, Alkud(M).
Office Address :400KV RS, Alkud(M), Tal: Kavathe Mahankal,
Dist: Sangli, Pin:416419
Contact No. :8411805664 / 02341-299081
Email ID :ee3170@mahatransco.in

Ref. No. EE/400KV RS DN ALKUD/T/No. 230

Date: 06/11/2023

E- Enquiry (Budgetary offer)


Sub: - Enquiry for submission of budgetary offer for Supply of spare material for 400KV, 3150Amp CB isolator & 220KV, 2000Amp DB isolator for 400KV RS Alkud under 400KV RS DN Alkud (M)

Dear Sir,

Sealed and super scribed budgetary offer are invited by the undersigned for the Supply of spare material for 400KV, 3150Amp CB isolator & 220KV, 2000Amp DB isolator for 400KV RS Alkud under 400KV RS DN Alkud (M) on or before: 15.11.2023.

The other terms and conditions are as mentioned below.


- 1) Quotation should be duly filled in and submitted to this office via **Post or e-mail – ee3170@mahatransco.in**
- 2) This enquiry is solely for collection of offer for estimate purpose & not for work allocation.
- 3) The offer should be submitted as per details mentioned below.
- 4) Quote rate in prescribed format and attached specifications in Annexure 'A'


(D. V. Bobade)

Executive Engineer (charge)
400 KV R.S. Dn., Alkud(M)

Annexure 'A'					
Supply of spare material for 400KV, 3150Amp CB isolator & 220KV, 2000Amp Double Break isolator for 400KV RS Alkud under 400KV RS DN Alkud (M)					
Sr. No.	Particular	Unit	Estimated Approx. Qty.	Rate per Unit	Amount
	Spares for 400KV 3150A CB Isolator, Make: GR power, type - HCB				
1	Terminal Contact (5 Pairs 32X6.2 HDECu Flat)	No.	4		
2	Female Contact Finger (32X6.2 Cu Flat, 5 Pairs Silver plated)	No.	2		
3	Male Contact (200X5 Cu Flat. 2nos. Silver Plated)	No.	2		
4	Contact Arm (180X95X5mm Thick Aluminum Alloy Extrusion Box type)	No.	4		
5	Down Operating Pipe	No.	1		
6	Universal Joint Assembly	No.	1		
7	MOM box output flange	No.	1		
8	Limit Switch (LSO)	No.	2		
9	Limit Switch (LSC)	No.	2		
	Spares for 220kV 2000A Double Break Isolator, Make: GR power, type - HDB				
1	Main Switch Female Contact Assembly	No.	4		
2	Main Switch Female Contact Fingers	No.	5		
3	Moving Contact	No.	1		
4	Reduction Gear Box	No.	1		

Above all rates should be exclusive of GST, Labour cess & all other applicable charges, should be mentioned separately if applicable. Estimate quantity is tentative & it may vary during the PO. The material will be used at 400KV RS, Alkud(M), hence to be confirm with actual equipment in service.



(D. V. Bobade)
Executive Engineer (charge)
400 KV R.S. Dn., Alkud(M)