



**MAHARASHTRA STATE ELECTRICITY TRANSMISSION  
CO. LTD.**

**Government of Maharashtra (undertaking)  
(CIN NO.U40109MH2005SGC153646)**

**From: Executive Engineer, EHV Projects Division-I, Pune  
Administrative Building, 3<sup>rd</sup> Floor, 925, Kasba Peth,  
Pune – 411 011.**

**PHONE NO. (020) 24579223 & 24572129  
E-Mail Id : ee6610@mahatransco.in**



**Ref.No.EE/EHV/Projects/DN-I/PN/Tech/1717**

**Date : 17.11.2023**

**To Whom So Ever It May Concern**

This office intends to carry out E-enquiry in r/o calling budgetary offer for monopole for Height increasing of existing 220 kV D/C Jejuri - Lonand & Lonand Baramati line between exi loc no 58 to 59 for 4 laning road from lonand to Diveghat by NHAI for Palkhi Mahamarg under EHV Project Division -1 Pune The details of the same are as below and scope of work is attached.

**It is hereby declare that this enquiry is treated as cancelled.**

**A. Supply Part**

| Sr. No.                              | Name of Item                            | Unit Rate | Qty | Excluding taxes | Amount |
|--------------------------------------|---|-----------|-----|-----------------|--------|
| 1                                    | Supply of 220kV 60°+ 24 (D/C ) monopole | Nos       | 2   |                 |        |
| Total Amount excluding taxes         |   |           |     |                 |        |
| Rs...../- In words (excluding taxes) |   |           |     |                 |        |

**B. Erection Part**

| Sr. No.                              | Name of Item                             | Unit Rate | Qty | Excluding taxes | Amount |
|--------------------------------------|--|-----------|-----|-----------------|--------|
| 1                                    | Erection of 220kV 60°+ 24 (D/C) monopole | Nos.      | 2   |                 |        |
| Total Amount excluding taxes         |  |           |     |                 |        |
| Rs...../- In words (excluding taxes) |  |           |     |                 |        |

**C. Foundation Part (70%DFR Soil & 30% BC soil)**

| Sr. No.                              | Name of Item                              | Unit Rate | Qty | Excluding taxes | Amount |
|--------------------------------------|---|-----------|-----|-----------------|--------|
| 1                                    | Foundation of 220kV 60°+24 (D/C) monopole | Nos       | 2   |                 |        |
| Total Amount excluding taxes         |   |           |     |                 |        |
| Rs...../- In words (excluding taxes) |   |           |     |                 |        |

**Note:-**

1. Above rates are excluding of all taxes.
2. The bidder should specify all taxes & statutory cess as extra specifically with their offer
3. The supply & fixing of tower accessories namely Danger board, circuit plate, phase plate, Number Plate, anti-climbing devices etc. shall be a part of above schedule.
4. The offer should be submitted by Manufacturer/ their authorized dealer or agency having experience of execution of Monopole works which including supply, erection & foundation. Please submit dealership certificate and/or experience certificate.
5. MSETCL has already issued guidelines regarding technical specifications of monopoles vide circular No. 0543 dtd 16-01-2019 ( copy is enclosed here with for ready reference). The bidder has to comply all technical specification mentioned in it and shall quote his offer accordingly.
6. The offer should be valid for at least 6 months.
7. Your offer should reach this office on or before 24-11-2023 upto 15:00 Hrs. by email on mail id [ee6610@mahatransco.in](mailto:ee6610@mahatransco.in) or in hard copy on office address
8. The right to accept offer for part or to cancel any or all budgetary offer without assigning any reason is reserved with undersigned.

**Terms and Conditions:**

Following are the site conditions and Monopoles are required to suit the site condition.

- 1) Monopole should be of Regular type and the spans between two poles ranges between 250 - 350 mtrs.
- 2) Soil type along the route is DFR & BC.
- 3) 0.4 ACSR (Zebra) conductor is to be used, thus monopole should be designed considering this conductor stringing.
- 4) Work is to be so planned & executed that it should be completed in minimum outage plan.

This Budgetary offer is invited only for estimation purpose and same will not be considered for any bidding. Please Note.

**NOTE: The said enquiry is cancelled.**

Sd/-  
Mahendra Katenge  
Executive Engineer  
**EHV Project Division-I Pune**