



**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.**

**Name of Office:** Office of the Superintending Engineer Protection Automation & Communication Circle, MSETCL, Chhatrapati Sambhajanagar. MSETCL, Administrative building, wing no.03, Jalgaon Road, Harsul, Chhatrapati Sambhajanagar.

E-mail Id : [setccabd1@gmail.com](mailto:setccabd1@gmail.com)  
[se2500@mahatransco.in](mailto:se2500@mahatransco.in)

SE/PAC/CSN/TS/No. **000093**

Date: **7 MAR 2024**

**E-ENQUIRY**

To,

**Subject:- E-Enquiry for work of procurement of 05 No.s of Restricted Earth Fault Relays under PAC Circle, Chhatrapati Sambhajanagar for F.Y.2023-24.**

Dear sir,

Sealed and super scribed quotations are invited from Dt.07.03.2024, so as to reach this office up to date 13.03.2024 for procurement of 05 No.s of Restricted Earth Fault Relays for ICT's and Power transformers at various EHV substations under PAC Circle, Chhatrapati Sambhajanagar for F.Y.2023-24 as detailed in Schedule 'A' enclosed herewith subject to the following terms and conditions:-

**Terms and Conditions:-**

- 1) Please refer the Schedule attached herewith and quote your offer for the same.
- 2) You should quote your rates for all items. GST rate as applicable will have to be quoted separately in space provided. If nothing is specified rates will be considered as inclusive of all taxes.
- 3) Documents required: Bidder should submit following valid documents along with quotations
  - a. Valid Electrical Contractor License.
  - b. Valid Goods & Service Tax(GST) registration certificate.
  - c. Valid Bombay Shop Act/MSME/NSIC registration.
  - d. PAN Card copy.
  - e. Proof of Income tax return of last financial year with PAN card copy.



#### 4) **SCOPE OF WORK:**

Supply of 05 No.s of Restricted Earth Fault Relays for ICT's and Power transformers at various EHV substations under PAC Circle, MSETCL, Chhatrapati Sambhajanagar

5) **Warranty Period:** The Warranty Period is one year from the date of delivery of the material.

6) **Security Deposit :** You will have to pay the security deposit within 7 days from date of receipt of supply order, (10%) of order value in the form of cash/FDR/D.D. of any Nationalized/Schedule Bank in the name of Superintending Engineer, EHV O&M Circle Chhatrapati Sambhajanagar payable at Chhatrapati Sambhajanagar. The Security Deposit will be refunded only after satisfactory completion of the warranty period.

7) **Agreement :** The Contractor will have to enter into an agreement within 7 Days from issue of this Order with MSETCL. The successful contractor shall submit the contract in the prescribed format on Non-Judicial Court Stamped paper of appropriate value i.e. Rs.500/- as per MSETCL admin circular no. 207 Dtd.17/04/2010. The cost of Stamp Paper will be borne by the contractor, since this Agreement is being executed by the contractor; it is the sole responsibility of the contractor guarantee the minimum wages as per prevailing Act including all statutory payments to the staff/labors.

8) **Liquidated Damages For Late Delivery:** In case the specified quality and/or quantity of items are not delivered within the period stipulated the supplier shall be liable to pay liquidated damages to the MSETCL at the rate half percent (1/2%) per week or part thereof for delay subject to maximum 10% of the total value of supply order.

9) **Income Tax:** The Income Tax as per the applicable rate of the gross bills payable will be deducted while making payments by this office to contractor. Income Tax deducted at source (T.D.S.) / necessary certificate will be issued to the contractor.

10) **Delivery Period:** All Material should be supplied within 90 days from the date of issue of this order.

11) **Bills:** Tax invoice bills in triplicate should be submitted to the Superintending Engineer PAC Circle Chhatrapati Sambhajanagar after supply of the relay.

12) **Payment:** 100% Payment will be given against delivery by account payee cheque in the name of Superintending Engineer, EHV O&M Circle Chhatrapati Sambhajanagar. After due audit the payment will be made by the Superintending Engineer, EHV O&M Circle Chhatrapati Sambhajanagar subject to the availability of funds. Bill shall be contained -

i) GST Tax Invoice ii) E-Way Bill in case material transported iii) Warranty Certificate issued by Original equipment manufacturer ( OEM).

13) **Replacement:** If Material gets defective or fails during warranty period due to any manufacturing defect on the part of manufacturer, the same will have to be attended/ replaced free of cost during warranty period for trouble free operation.



14) **General Conditions for supply:** The agency is presumed to be aware of the company's general conditions for supply contract which are binding as they are applicable to this order. Similarly, all terms and conditions of order under reference are also binding on you.

15) **Consignee for Supply:** The Consignee is the Superintending Engineer PAC Circle MSETCL Chhatrapati Sambhajnagar.

16) **Jurisdiction:** In case of any dispute arising out of your Contract, it will be in the Jurisdiction of Chhatrapati Sambhajnagar Court only.

17) **Termination of Contract:** In case the supplier fails to deliver the required quantity of material or any consignment thereof within the contracted period of delivery or in case the material found not in accordance with prescribed specification and the approved samples, the MSETCL shall exercise its discretionary power either.



(S.M.Suradkar)

Superintending Engineer,

PAC Circle, Chhatrapati Sambhajnagar.

**Copy f.w.c.to:** 1. The Superintending Engineer, EHV O & M Circle, Chhatrapati Sambhajnagar.

**Copy to:** 1. The Sr. Manager F&A, EHV O&M Circle, Chhatrapati Sambhajnagar.

2. MSETCL Web

Encl: Schedule A

**Copy f.w.c.to:** 1. The Superintending Engineer, EHV O & M Circle, Chhatrapati Sambhajnagar.

**Copy to:** 1. The Sr. Manager F&A, EHV O&M Circle, Chhatrapati Sambhajnagar.  
2. MSETCL Web





# **MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD**

## **SCHEDULE 'A'**

**Subject: - Procurement of 05 No.s of Restricted Earth Fault Relays for ICT's and Power transformers at various EHV substations under PAC Circle, Chhatrapati Sambhajnagar for F.Y.2023-24**

Sr. No.	Particulars of work	Unit	Required Quantity	Rate in Rs.
1.	<p>Procurement of 05 No.s of Restricted Earth Fault Relays for ICT's and Power transformers at various EHV substations under PAC Circle, Chhatrapati Sambhajnagar for F.Y.2023-24</p> <p>The specification of above relays is as below:</p> <p>Current Operated High Impedance REF Relay</p> <p>DC Supply:80-240V</p> <p>DC(Universal)</p> <p>Nominal current: 1 A</p> <p>I/P- Minimum: 8 input</p> <p>O/P-Minimum: 8 output</p> <p>DI Threshold:</p> <p>77VDC for (110V DC Supply Voltage)</p> <p>154VDC for (220V DC Supply Voltage)</p> <p>Stabilizing Resistor- 0-1000 ohms,200 watts</p> <p>Metrosil- Suitable for 1A CT.</p>	Nos.	05	

**S.M.Suradkar**  
**Superintending Engineer,**  
**PAC Circle, Chhatrapati Sambhajnagar.**