

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD
(CIN NO- U40109MH2005SGC153646)

Office of the,
Executive Engineer
MSETCL EHV O&M, Division,
Near Market Yard, Bapat Camp, Kolhapur
Tal: - Karvir, Dist-Kolhapur-416 005
E-mail: - ee3210@mahatransco.in
Mobile: - Off-0231-2651529, Fax-0231-2680171

MSETCL/EE/EHV O&M/Dn./Kop/T/LP/741

Date : 25.04.2024

E- Enquiry (Budgetary offer)

Sub : - Enquiry for submission of budgetary offer for Supply of 3 No's of 33kV, 2000-1000/1A, 4C CT at 220kV Five star MIDC substation under EHV O&M Division Kolhapur

Dear Sir,

Budgetary offer are invited by the undersigned for Supply of 3 No's of 33kV, 2000-1000/1A, 4C CT at 220kV Five star MIDC substation under EHV O&M Division Kolhapur **on or before: 03.05.2024 up to 10:00 Hrs.** The other terms and conditions are as mentioned below.

- 1) Quotation should be duly filled in and submitted to this office **via post or e-mail** – ee3210@mahatransco.in
- 2) **This enquiry is solely for collection of offer for estimate purpose & not for work allocation.**
- 3) The offer should be submitted as per details mentioned below.
- 4) **Quote rate in prescribed format & Attached Specifications::**

A) Details are below:

Particular	Unit	Rate per unit (Incl. of All Taxes)
Supply of 33KV Outdoor , Oil cooled , Dead Tank CT. Single Phase wound Primary. The detail specifications are as below:- Make:- Any Standard:CT Ratio:- 2000-1000/1A Core:- 4C (Core 1,2 & 4 :- PS Class, Core 3:- 20VA, Accuracy class :- 0.2 S, ISF<=5 For PS Class:- $V_k=RCT@75 \text{ degree } +19)^*15$ STC:-26.2KA/sec Creepage distance:- 25mm/KV frequency:- 50Hz Insulation Class:- A IS :- IS 2705/1992	No.	

(Aftab Khan)
Executive Engineer
EHV O&M Dn. Kolhapur.