

Requirement of Budgetary Offers

Sub.: Requirement of Budgetary Offers for the Supply of Transducers for WTI, OTI and Tap Position Indicators for ICTs and Power Transformers installed at 400kV RS, Kharghar

Budgetary offers are being invited the Supply of Transducers for WTI, OTI and Tap Position Indicators for ICTs and Power Transformers installed at 400kV RS, Kharghar. The specifications are as given below-

Sr. No.	Particulars	Qty.
1	PSU/Remote indicator suitable for Precimeasure make WTI /OTI : - Signal input: Suitable for connection from built-in CCU inside Local OTI/WTI - Auxiliary supply input: 90-260v AC/DC - Signal Output: 2Nos. 4-20mA DC -Burden on signal outputs: Maximum 600ohm including loop resistance - Mounting: Din rail - Degree of protection : IP 40 for housing & IP 10 for terminals - Power Consumption: 3Watts	24
2	Tap Position Indicator: Max. No. of tap positions: 25 or as specified Step resistance / tap: $1K\Omega \pm 1\%$ or as specified Power Consumption: 95 to 260 V AC/DC Output: 2 Nos 4-20 mA O/P for SCADA	8

The interested vendors are requested to submit your Budgetary Offer by either of the modes of communication i.e. E-mail/Post/Courier, so as to reach this office (E-mail id and address are as given below) by **29.05.2024**. The preference will be given to trusted suppliers and MSETCL's registered vendors.

E-mail id: ee7220@mahatransco.in

Address: Office of the Executive Engineer, 400kV RS O&M Dn., Kharghar, MSETCL, Sector-6, Near Utsav Chowk, Kharghar, Navi Mumbai, District.Raigad-410206

SD/-
Executive Engineer (I/C.),
400kV RS O&M DN., Kharghar