

 <p><b>MAHATRANSCO</b> Maharashtra State Electricity Transmission Co. Ltd.</p>	<p><b>MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED</b> Government of Maharashtra (Undertaking) (CIN No- U40109MH2005SGC153646) Office of the Executive Engineer 400kV R.S. Division, Lonikand-II Sambhaji Nagar, At post-Lonikand, Tal-Haveli, Dist-Pune Maharashtra-412216 Phone no.-8208454909 Email:ee6190@mahatransco.in</p>	
---	--	--

EE/400kV/RSO&M/Div/Lonikand-II/243

Dt:05.08.2024

**TO WHOM SO EVER IT MAY CONCERN**

**Sub:** - Calling budgetary offer for estimation purpose of Supply, Installation, testing & Commissioning of 100% Hot Redundancy based continuously available fire alarm panel & false alarm filtering type detector at 400kV R.S. Division, Lonikand-II.

**Dear Sir,**

The budgetary offers through email are hereby invited for estimation purpose of Supply, Installation, testing & Commissioning of 100% Hot Redundancy based continuously available fire alarm panel & false alarm filtering type detector at 400kV R.S. Division, Lonikand-II. Accordingly, it is requested to submit the budgetary offer for below mentioned work.

**‘Schedule A’**

S.N.	Particular	UOM	Quantity	Ex rate	GST	Unit rate
<b>A</b>	<b>Supply Portion</b>					
1	2 Loop Intelligent Addressable, IP Based Fire Alarm Control Panel, Supports as needed etc.	No.	1			
2	Intelligent Addressable MULTI CRITERIA DETECTOR WITH BASE and inbuilt short circuit Isolator, Settable as smoke / Heat / both for Sensing full range of TF-1 to TF-8 Fires.	No.	98			
3	Intelligent Addressable Manual Call Point with inbuilt Short Circuit Isolator and with IP 67 Protection and Supporting Structural etc.	No.	12			
4	Intelligent Addressable Multi tone Hooter with inbuilt Short Circuit Isolator with supporting Accessories with Sounder Cover	No.	11			
5	1.1kV PVC FRLS 2Cx0.5 Cu Arm Ctrl Cable for Loop Cabling in Cable Trays in Trenches and other required Installation materials.	RMT	4200			
6	GI Conduit pipe 50mm	RMT	1250			
<b>B</b>	<b>Service portion</b>					
1	Installation of System Software for System Integration by Loop Scanning by Addressing and Programming, Commissioning and Performance Testing.	No.	1			
2	Installation of GI conduit pipe 50 mm	RMT	1250			

**Note:** - Rate shall be valid for 90 days from the date of submission of offer.

You are requested to quote your best reasonable rate for the above work. The terms & conditions are as follows.

**Terms & conditions:**

1. The rates should be quoted on firm quotation basis.
2. The rates should be exclusive of taxes, taxes should be quoted extra.
3. You are requested to submit your best reasonable budgetary offer as per schedule A for above mentioned subject on email Id: [ee6190@mahatransco.in](mailto:ee6190@mahatransco.in) upto 18:00 Hrs on dtd-12.08.2024

**Following documents should be submitted along with your offer.**

1. Shop act / Udyog adhar Registration Certificate.
2. Maharashtra Fire License
3. Work experience certificate/Work order/ any evidence for said work done in MSETCL or any Govt institution.

*Please note that said budgetary offer is only for estimate purpose & will not be considered for any bidding & no work order will be issued based on this offer.*

For any doubt about the meaning of any portion, conditions you should get it clarified from the office of the undersigned before submission of the offer.

Thanking You,

Sd/-  
**Sanjaykumar Ramteke**  
**Executive Engineer**  
**400kV R.S. Division, Lonikand-II**