

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

FROM:
THE EXECUTIVE ENGINEER
TESTING Dn, 1st FLOOR, BLOCK NO. 5,
NEW ADMINISTRATIVE BUILDING,
NEAR DURGAMATA MANDIR,
OLD SAIKHEDA ROAD, JAIL ROAD, NASHIK
Email Id. ee5150@mahatransco.in

No.: EE/TD/NSK/Tech/T-17/622

E-enquiry

Date:- 23.10.2017

Sub:- E-Enquiry for 2Nos of AC leakage clamp meter (mA Range) /Tong Tester for Testing Unit BBLR under Testing Division, Nashik.

Dear Sirs,

Please offer your reasonable rates for 2nos of AC Tong Tester/Clamp on meter,

1. SPECIFICATION OF METER:

- Display: 3 1/2 digit L.C.D.
- Jaw Opening Capacity: 40mm diameter.

Range	Resolution	Accuracy
Min. 30/300 mA	0.01 mA	+/- 1.2% of reading +/- 5 digits
Max. 30/300 A	0.1 mA	Range: 0-30A +/- 1.2% of reading +/- 5 digits Range: 0-300A -1.2% of reading +/- 5 digits (Better accuracy & other features are accepted at par with basic requirement.)

2. DUE DATE: The quotations complete in all respects, dully sealed & superscribed should be submitted to this office on or up to 08.11.2017 up to 15:00Hrs.


3. QUOTED RATES: The taxes applicable if any should be quoted distinctly.

4. VALIDITY OF OFFER: The offer should be valid for our acceptance for period of 60 days from the due date of opening.

The undersigned reserved the right to reject any or all quotations without assigning any reason.

Thanking You,

Yours faithfully


Executive Engineer
MSETCL Testing Dn Nashik

Copy s.w.r.to:-

- 1] The C.E. (EHV Project O&M) Zone/MSETCL/Nashik.
- 2] The S.E. (EHV O&M) Circle/MSETCL/ Nashik.
- 3] The S.E. TCC, Nashik.