

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

CIN No. U40109MH2005SGC153646

Name of Office :- EHV (O&M) DIVISION, NANDED.
**Office Address :- 132 KV S/S JANGAMWADI, CAMPUS, MSETCL
NANDED- 431605**
**Contact No. :- 02462 – 261817 (O), 02462 – 261817 (Fax)
02462 – 261816 (P)**
Email :- ee2240@mahatransco.in ; eenanded@gmail.com

Ref. No. EE/EHV(O&M)/NND/TS/ File No.73/ 814 - Date :- 13 JUL 2018

E-Enquiry

To,

Subject:- E-Enquiry for work of DGA testing by Mobile Lab of T/F oil and other tests of oil for ICT's & transformers at various sub-stations under EHV(O&M) Division, Nanded.

Dear Sir,

Sealed & super scribed quotation are invited from date **16.07.2018**, so as to reach this office up to date **24.07.2018** for the work of DGA testing by Mobile Lab of T/F oil and other tests of oil for ICT's & transformers at various sub-stations under EHV(O&M) Division, Nanded on following terms & conditions:-

TERMS AND CONDITIONS:-

1. The Rate shall be quoted on firm quotation basis.
2. The Schedule 'A' duly filled in with the rates quoted in Rs./per sample should be sent by registered post or in person to the Office of the Executive Engineer, EHV (O & M) Division, Nanded on or before 24.07.2018 up to 17:00Hrs.
3. Please super-scribe the offer with the following details.
 - a) Quotation for:
 - b) Due Date:
 - c) Name of the bidder:
4. The Offer shall be valid for acceptance for the period of 30 from the date of submission.
5. Following documents should be attached with quotations
 - a) Valid Electrical Contractor License, Shop act certificate.
 - b) Valid GST Registration Certificate & pan card.
 - c) Valid Certificate from the National Accreditation Board for testing & calibration Laboratories (NABL).
 - d) Work experience certificate received from an officer not below the rank of Executive Engineer for having successfully completed similar type of work.
6. **Offer received without above documents will be liable for rejection.**
7. All the documents of this enquiry Schedule 'A' and other accompanying documents shall bear the authorized signature of the agency, failing which the offer will be liable for rejection.

8. The agency should not submit 'conditional quotations'. In case such conditional offers if received shall be rejected.
9. If the agency has any doubt about the meaning of any portion of the enquiry conditions/ specifications, he should get it clarified from the office of the undersigned before submission of the offer.
10. Any scratching or overwriting on quotations will not be allowed. Any such quotations, if received will be liable for rejection.
11. You will have to pay security deposit @ rate 5% of the order value which will be returned to you after successful completion of work.
12. You will have to complete entire work within 2 months after handing over of site to you. If you fail to complete the work within stipulated period, penalty at the rate of ½ % of the order value per delayed week or part thereof subject to maximum of 10% shall be recovered from your bill.
13. Income tax and all other taxes if applicable will be deducted as per rules.
14. The undersigned reserved the right to reject any or all quotations without assigning any reasons thereof.
15. All General / Technical/ commercial terms & Conditions of the contract of the company are applicable to this contract.

Thanking you.

Yours faithfully,

— Sd —

Executive Engineer
EHV(O&M) Division Nanded.

Copy SWRT:-

The Superintending Engineer, EHV O&M Circle Parli V

Copy to:-

1. The Mgr (F&A), EHV O&M Division Nanded.
2. Website:- www.mahatransco.co.in

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.
EHV (O&M) DIVISION, NANDED.

Schedule

Work of DGA testing by Mobile Lab of T/F oil and other tests of oil for ICT's & transformers at various sub-stations under EHV(O&M) Division, Nanded.

Sr. No.	Particulars	Quote your Rate/sample
1	Testing of Transformer oil at various EHV Substations under EHV O&M Division Nanded with following Tests	
	Taxes (if any)	

Sr.No.	Test to be Carried out	Specification Standard Method
1	Break Down Voltage	IS: 6792 : 1992
2	Dielectric Dissipation Factor at 90°C	IS : 6262 : 1971
3	Resistivity at 90°C	IS : 6103 : 1971
4	Appearance	IS : 335 : 1993
5	Density at 29.5 °C	IS : 1448 : 1990 (Part-16)
6	Kinematic Viscosity at 27 °C	IS : 1448 : 1976 (Part-25)
7	Inter Facial Tension	IS : 6104 : 1971
8	Flash Point	IS : 1448 : 1992 (Part-21)
9	Pour Point	IS : 1448 : 1970 (Part-10)
10	Neutralization Value	IS : 1448 : 1967 (Part-2)
11	Water Contents	IS : 13567 : 1992
12	Sediment and Sludge	IS : 9434:1992
13	Dissolved Gas Analysis CO, CH ₂ ,CO ₂ , C ₂ H ₄ , C ₂ H ₂ & H ₂	IS : 9434 : 1992

NOTE: _ Order Value will be limited upto Rs. 3.0 Lakhs (Inclusive of all taxes)

— Sd —
Executive Engineer
EHV(O&M) Division Nanded.