

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD
CIN No- U40109MH2005SGC153646

Executive Engineer Telecom Division, Aurangabad
wing No 3 Ground floor, New Administrative Building
132kV Harsool Premises Sillod Road
Aurangabad-431008
0240-2348351(O), 2331097
E-mail Id :eeabdtel@gmail.com, ee2510@mahatransco.in

No.EE/ABD/TCD/TS/ 738/

Date: 28.12.2018

E-ENQUIRY

Sealed and superscribed quotations are invited for Supply of Line matching units at Telecom S/Dn Parli

The quotation giving full details of your terms and conditions for delivery, validity of the rate, should reach this office on or before **10.01.2019**. You are requested to quote your reasonable rates with due consideration of the following points.

- 1) The rates quoted shall be exclusive of all taxes and delivery to Additional Executive Engineer Telecom S/Dn (Address: Old Power House, Opposite EHV O&M Circle Parli) Taxes should be quoted extra.
- 2) GST registration & PAN number should be mentioned on quotation.
- 3) Material shall be warranted for minimum 1 year.
- 4) Material shall be provided as per Schedule 'A' & 'B'
- 5) The rates quoted shall be on firm quotation basis.
- 6) The envelope should be super scribed as "QUOTATION FOR SUPPLY OF LINE MATCHING UNIT".
- 7) **Material to be as per approved drawings of MSETCL standards.**
- 8) The documentation containing details of Line Matching units of manufacturer to be supplied should be enclosed along with quotation such as make, type/model, specifications etc.
- 9) The right to reject any or all the quotations and Enquiry is reserved by the undersigned.
- 10) Payment will be effected in reasonable time after supply of material in good condition & submission of bills.
- 11) Agency shall pay 10% of order value as security Deposit. This Security Deposit will be paid after completion of warrantee period.
- 12) Jurisdiction: All quotation disputes or difference as under out of or in connection with the contract if concluded shall be subject to the exclusive jurisdiction of the Aurangabad Court.

Executive Engineer
Telecom Division Aurangabad

Encl: Schedule 'A' & Schedule 'B' typed on overleaf.

Copy to –

- 1) Notice Board & MSETCL website



MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD

SCHEDULE 'A'

Name of Work: Supply of Line matching Unit for 220kV Parli Osmanabad line

Sr No	Name	Qty	Unit Price	Amount
1	Line matching unit 200W (A & B unit)	2 Sets		
	Total			
	GST 18%			
	Grand Total			
			Round off	

Note: -

1. Taxes shall be quoted separately otherwise it will be assumed as inclusive of taxes.
2. The documentation containing details of material of manufacturer to be supplied should be enclosed along with quotation such as make, type/model, specifications, etc.

**Executive Engineer
Telecom Division Aurangabad**

Schedule: B

Specifications: -

High degree of modularity Compact unit with variable complement of modules – Maximum personnel protection Insulated enclosure and special design features minimize electrical hazards – Programmable One high-pass version for different system parameters, programmable on site – Weather-proof and tropicalized Corrosion inhibited by fiberglass reinforced polyester enclosure – High carrier power rating Up to 1000 W PEP – ISO 9001 quality – Simple integration in PLC system

High-pass filter A Type

Nominal impedance PLC equipment-side Z2 75 Ω and 125 Ω , unbalanced

Nominal impedance transmission line-side Z1 240/320 Ω

Range of coupling capacitance 1.5 to 13 nF

Composite loss within passband \leq 1.0 dB typical

Return loss within passband \geq 12 dB typical

Band-pass filter B Type

Nominal impedance PLC equipment side Z2 as desired

Nominal impedance transmission line side Z1 as desired

Range of coupling capacitance min. 0.5 nF

Composite loss within passband \leq 1.0 dB typical

Return loss within passband \geq 12 dB typical

Common filter properties

Average continuous power (frequency dependent) 200 W typical

Nominal peak power P.E.P. at 50 kHz \leq 400 W

at 100 kHz \leq 1000 W

Non-linear distortion 2-tone test P.E.P. 400 W, f1 = 54 kHz, f2 = 66 kHz

Intermodulation 3rd & 5th order \geq 80 dB

Harmonic distortion \geq 80 dB

Power frequency test voltage

Transformer (primary/secondary) 10 kVrms, 1 min

Hybrid (windings/windings) 5 kVrms, 1 min

Impulse test voltage wave shape 1.2/50 μ s

Transformer (input line-side to ground) 10 kVpeak

Hybrid (inputs against ground) 5 kVpeak

Crossover attenuation of hybrid A1AC \geq 20 dB

Drain coil

High-pass A9BS/A9BT

Inductivity adjustable depending on selected programming 0.2 to 0.7 mH

Impedance at mains frequency \leq 1.5 Ω

Band-pass A9BP/A9BR

Inductivity 40 mH

Impedance at mains frequency \leq 20 Ω

Common features

Continuous current \leq 1.5 Arms

Short-time current \leq 50 A, 0.2 s

Earthing switch

Rated current 300 Arms continuously

Short-time current 16 kA, 1 s

Surge arrester

Rated voltage 660 V

Max. 100% impulse spark-over voltage (1.2/50 μ s) 3300 Vpeak

Rated discharge current (8/20 μ s) 5 kApeak

Connections

Equipment side

Terminal blocks for max. cross section 4 mm²

4 cable glands (2 x M20 and 2 x M25) for cable diameter 3 -12 mm (M20) and 5 -17 mm (M25)

Line side and earthing

Connecting bolts with metric threading M10

Permissible ambient temperature range - 40 °C to + 70 °C

Weight (per unit)

A type approx. 9 kg (20 lbs)

B Type approx. 10 kg (22 lbs)

Executive Engineer
Telecom Division Aurangabad