

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD
(CIN No.U40109MH2005SGCI53646)**

Office of the Executive Engineer

EHV O & M Division-I, Pune

Block No.406, Administrative Building, 3rd Floor, Rasta Peth, Pune – 411011

Phone No : 26131362 (O), Fax No.: 26053991 E-mail- ee6140@mahatransco.in

EE/EHV O&M Dn.-I/Pune/Tech./ 844

Date :15.05.2019.

TO WHOM SO EVER IT MAY CONCERN

This office required the budgetary offer for the work mentioned below.

A. Replacement of Buchholz relay isolation valve, Main Conservator Oil Inspection glass & PRVs for 200MVA, 220/132 kV, ICT No. 1 Make M/s EMCO at 220kV Theur Substation.

B. Replacement of existing Main Conservator & replacement of Valves of different sizes of 50MVA ,220/22kV, TF no.5 Make M/s BHEL (AVAL repaired) at 220kV Theur Substation.

All interested bidders are requested to submit their best reasonable budgetary offer on Email ID:ee6140@mahatransco.in along with HSN code/ SAC Codes & applicable rate of GST for above Material & service, upto dtd. 21.05.2019. You may visit at 220kV Theur Substation to observe exact situation before submitting the budgetary offer & it is also requested to suggest changes in Scope, if required as per site condition.

Please note that this budgetary offer is for estimation purpose only .

Encls:- Schedule “A”

- Sd -

[P.M. Pawar]

**Executive Engineer,
EHV O&M Division-I, Pune.**

This office required the budgetary offer for the work mentioned below.

- A. Replacement of Buchholz relay isolation valve, Main Conservator Oil Inspection glass & PRVs for 200MVA, 220/132 kV, ICT No. 1 Make M/s EMCO at 220kV Theur Substation.**
B. Replacement of existing Main Conservator & replacement of Valves of different sizes of 50MVA ,220/22kV, TF no.5 Make M/s BHEL (AVAL repaired) at 220kV Theur Substation.

Schedule 'A'

| Sr. No. | Particulars of work | Unit | HSN / SAC Codes | Estimated Rate in Rs. | GST applicable in % | Qty. | Estimated Amount in Rs. |
|----------------------------------|--|------|-----------------|-----------------------|---------------------|------|-------------------------|
| Labour Portion | | | | | | | |
| For 220/132kV, 200MVA ICT | | | | | | | |
| 1 | Replacement of PRV, plain oil gauge & Gun Metal valves by draining of oil upto core level & topping up of oil after filtration work | | | | | | |
| For 220/22kV, 50MVA T/F | | | | | | | |
| 2 | Main tank to Conservator pipe modification for Valve fitting | | | | | | |
| 3 | Replacement of Gun Metal valves by draining of oil & topping up of oil after filtration work of different sizes | | | | | | |
| 4 | Fixing of Air Cell | | | | | | |
| 5 | Fabrication of conventional Main Conservator tank for provision of Air cell i.e. to fixing adjustable flange at top of breather pipe line along with air vents at top side , air cell holding a cell, cover plate for pipe at bottom & mesh for air cell support rest. | | | | | | |
| 6 | Provision of both sides Dummy plates of Main conservator tank to facilitate manual entry to work. | | | | | | |
| 7 | Fabrication to both sides cover plates of Main conservator tank for plain oil gauges & MOG | | | | | | |
| 8 | Modification to support structure and equaliser pipe of Main Conservator tank as per site condition | | | | | | |
| 9 | Internal Painting of Main conservator tank with two coats of oil resistant paint. | | | | | | |
| 10 | External Painting of Main conservator tank with two coats of high glossy heat resistive gray paint. | | | | | | |
| 11 | Erection, Testing & commissioning of Air Cell and Main Conservator tank at site with all required modifications | | | | | | |
| | | | | | | | |

Note: Conservator will be transported to your site for required fabrication & modification, if required. After completion of modification work, the agency has to fix/ erect the conservator properly & to the satisfaction of the SSI, 220 kV Theur Substation .

