

**Maharashtra State Electricity Transmission Co. Ltd**  
**(CIN: U40109MH2005SGC153646)**

<b>From</b> Name of Office: Executive Engineer, 400KV R.S. (O&M) D/n, MSETCL, Jejuri Office Address: A/P Jejuri Tal.Purandar,Dist.Pune. E mail ID: ee6160 @mahatransco.in;	<b>To</b>  <b>Website Publication</b>
--	---

**Ref. No. EE/400 KV/JEJURI/Tech/2020-2021/123**

**DATE:05.06.2020**

**ENQUIRY**

**Sub:** Enquiry for the work of replacement of 245 kV Bushing in r/o 167 MVA( R Phase Unit ) and faulty Air cell in r/o( B Phase unit) of 400/220/33 kV, 3 x 167 MVA ,ICT-2 Bank at 400 kV RS Jejuri.

**Dear Sir,**

You are requested to submit your offer **in sealed & superscribed envelops** for the work of replacement of 245 kV Bushing in r/o 167 MVA (R Phase Unit) and faulty Air cell in r/o (B Phase unit) of 400/220/33 kV ,3 x 167 MVA ,ICT-2 Bank at 400 kV Rs Jejuri as as per schedule 'A' **so as to reach this office on or before Dt.16.06.2020 upto 15.00Hrs** considering following terms and conditions:-

**TERMS AND CONDITIONS:**

1. The prescribed form i.e. Schedule 'A' duly filled in with the rates written in words and figures and signed should be sent by registered post or in person to **The Executive Engineer, 400KV R.S. (O&M) Divn. Jejuri,A/P Jejuri Tal.Purandar,Dist.Pune.**
2. Please super scribe the offer with the following details :-
  - a. Quotation for :-
  - b. Due Date :-
  - c. Name of the Bidder :-
3. The offer shall be valid for acceptance for a period of 90 days (Ninety days) from the date of submission. During this period no bidder shall be allowed to withdraw his offer.
4. All the documents of this Enquiry, Schedule "A" and other accompanying documents shall bear the authorized signature of the bidder, failing which the offer will be liable for rejection.
5. The bidder should quote rate including GST in %(Percentage) basis of estimate rate only.
6. The successful Bidder shall pay 5% of the contract value towards security deposit within 07 days from date of issue of work order.
7. The certified true copy of below mentioned documents should be attached along with quotation .
  - a)Pan Card
  - b) Valid Registration under shop and establishment Act /NOC of grampanchayat/Udyog Aadhar whichever is available / applicable.
  - c) Valid Registration of GST (if applicable).
  - d) Valid Electrical contractor Licence. .
  - e) The contractor should have minimum 2 years experience in r/o EHV substation of similar work . Certificate of performance of similar work in Govt. department, public sector not below the rank of Executive Engineer in any other power sector utility.

8. The bidder is in his own interest expected to visit the site and acquaint himself with the site conditions all other conditions which will affect the work.
9. The documents of an offer shall be written legibly and free from erasures, overwriting or conversion of figures corrections where unavoidable shall be made by crossing out, rewriting, initialing and dating.
10. Quotations which do not fulfill all or any of the above conditions or are incompleteness in any respect are liable to be rejected.
11. If the bidder has any doubt the meaning of any portion of the enquiry conditions/specifications he should get it clarified from the office of the undersigned before submission of the offer.
12. All general/Technical/Commercial terms and conditions of the contract of the Company are applicable to this contract.
13. The right to reject all or any of the quotation with assigning reason, whatsoever for the rejection of any quotation or all the quotations or to place an order for full quantity or part thereof or to finalize the order on time preferred basis or to split the order quantity wise is reserved with the undersigned.
14. The successful Bidder should have execute the agreement on Rs.500/- in bond paper within 07 days from date of issue of work order & cost of agreement to be borne by your account.

Thanking you,

Yours faithfully,  
Sd/-

S.C.Pardeshi  
**Executive Engineer**  
**400KV RS(O&M)Division**  
**MSETCL, Jejuri**

**Enclose: Schedule 'A'**

Copy.s.w.r.to:

1) The Superintending Engineer,EHV O & M Circle Pune

Copy to:-

1)The Add.EE(M),400KV RS Jejuri

2)Dy.Manager(F&A),400KV RS Div.Jejuri.

3)Notice Board.

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.,  
400KV R.S. (O&M) DIVN. JEJURI**

**SCHEDULE "A"**

**Description of Work:** Work of replacement of 245 kV Bushing in r/o 167 MVA (R Phase Unit )and faulty Air cell in r/o (B Phase unit)of 400/220/33 kV 3 x 167 MVA ICT-2 Bank at 400 kV RS Jejuri

Sr. No	Particulars	SAP Code	Qty	Unit	Unit price in Rs. Including GST & Labour Cess	Total Amount (Rs.)
1	Replacement of 245KV Bushing with allied works of R- Ph unit .	50001905	1	EA	88,500	88,500
2	Providing & Fixing of Aircell(Baloon) in Conservator of B- Ph Unit.	50009041	1	EA	103,686.60	103,686.60
3	Testing of air cell by filling dry air / N2 gas, firstly on ground & checking for any leakages visual inspection etc. After fixing / fitting of aircell refilling of N2 / Dry air at standard pressure.	50005480	1	EA	14,897.50	14,897.50
4	By draining & refilling of oil. Checking & attending oil leakages on conservator tank if any.	50017946	2500	Ltr	3.57	8,925
5	Providing & Fixing of Gasket - 09 mm thick gasket ring	50017418	1	EA	3,873.35	3,873.35
6	Providing & Fixing of Gasket - 06 mm	50005372	1	EA	1,334.82	1,334.82
Grand Total						221,217.27
Say						2,21,217/-

The total estimated cost is Rs.2,21,217/- inclusive GST & Labour Cess.

**The Bidder should Quote \_\_\_\_\_ % Above / At Par / \_\_\_\_\_ % Below of these estimated cost.**

Yours' faithfully,

Sd/-

**S.C.Pardeshi**

**Executive Engineer**

**400KV RS(O&M)Dn.Jejuri**