

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO LTD
(CIN No.U40109MH2005SGCI53646)

From

Office of the Chief Engineer

EHV Project Cum O&M Zone, Pune

Administrative Building, 3rd floor, Block No.402, Rasta Peth, Pune-411 011 ☎ 26136106, 26129913, 26137132 (P), 26136596(Fax) E-Mail: cepune@mahatransco.in

REF No.:- CE/EHV PC O&M ZONE PUNE/TECH/ 1752

DATE:- 18.11.2021

E-ENQUIRY

(through MSETCL webpage)

TO WHOM SO EVER IT MAY CONCERN

Dear Sir,

The budgetary offers through mail are invited for the above work as per Schedule 'A'.
You are requested to quote your lowest rate for the above work.

Schedule 'A'

Sr. No.	Scope of work	UOM	Ex Rate	Extra Taxes	Unit Rate
1	Supply of Head Lamp (1 Watt, LED, 4 hr backup. Rechargeable, maintenance free, compact & light in weight) As per technical specifications mentioned in Annexure I enclosed h/w.	Nos			
2	Supply of Beam Light (3 Watt, LED, 3 hr backup. Rechargeable, maintenance free, portable, light in weight) As per technical specifications mentioned in Annexure I enclosed h/w.	Nos			

- 1) Following documents should be submitted along with your offer:-
Experience certificate for Supply of portable LED lights (head lamp & beam light) in any Power Transmission/Distribution/Private Utility in India.
- 2) **Please note that, said budgetary offer is only for estimate purpose & not considered for any bidding & No work order will be issued based on this Enquiry.**
- 3) All interested bidders are requested to submit their best reasonable budgetary offer for above works on **Email ID:- cepune@mahatransco.in upto 11:00 Hrs on dtd. 25.11.2021.**

Thanking you,

Yours Faithfully,

Sd/-

(J.D.Weeky)

CHIEF ENGINEER
EHV PC O&M ZONE, PUNE

ANNEXURE- I

TECHNICAL SPECIFICATIONS for Head Lamp:-

Supply of **Head Lamp** (1 Watt, LED, 4 hr backup. Rechargeable, maintenance free, compact & light in weight) having following specifications:-

- Nickel Metal Hydride Alkaline battery;
- Head lamp should be sealed strappable with extension cord & connecting jack;
- Compatible for connecting to a DC power source of 6.5 V;
- 1 Watt, LED;
- 4 hour back when fully charged;
- Light in weight;
- Deep charge cut off at 4 Volts.

TECHNICAL SPECIFICATIONS for Beam Light:-

Supply of **Beam Light** (3 Watt, LED, 3 hr backup. Rechargeable, maintenance free, portable, light in weight) having following specifications:-

- Nickel Metal Hydride Alkaline battery;
- Beam light should be sealed;
- With 4 volts DC power pack;
- Transformer less trickle charging system;
- Deep charge cut off at 3 Volts;
- 3 Watt, LED;
- 3 Hours back up when fully charged.
- Weight should be less than 850 grams.

Sd/-

(J.D.Weeky)
CHIEF ENGINEER
EHV PC O&M ZONE, PUNE