

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.
CIN NO-U40109MH2005SGC153646

Executive Engineer, MSETCL, EHV O&M Dn., Sangli
Office building, Vishrambag, Tal- Miraj Dist. Sangli- 416415
Contact No.-0233-2305816 (O), 0233- 2304872 (P), 0233-2304873 (F)
E-mail ID – ee3120@mahatransco.in Website – www.mahatransco.in

Ref No. EE/EHV O&M/Dn/SGL/T/No. **01161** Date **7 SEP 2022**

TO WHOM SO EVER IT MAY CONCERN
BUDGETARY OFFER

Please find herewith a detail schedule "A" as per the following for Providing & Fixing Rotating Bird Guard/ Turbo wind Driven Insulator Protector for EHV Lines under LMSD Vishrambag & Borgaon under EHV O&M Division, Sangli.

All interested & experienced bidders are requested to submit their best lowest budgetary offer on the Mail ID: ee3120@mahatransco.in for the same upto Dtd.14/09/2022 upto 18:00 Hrs. Taxes should be quoted distinctly if any.

Please note that this budgetary offer is for estimation purpose only.


SCHEDULE 'A'

Sr. No.	Description	Unit	Qty	Rate / Unit	% GST	Remark
1	<p>Providing & Fixing of Rotating Bird Guard for EHV Lines under LMSD Vishrambag & Borgaon under EHV O&M Division, Sangli. Specification is as below</p> <p>1. Size: - Should be Maintained Standard Electrical Clearances on EHV Lines Phases. Neck Diameter :- 300 MM, Overall Height :- 350 MM, Spinning Diameter :- 375 MM 2) Material Grade for Fins & Frame: Almn. 8055 3) Nominal Thickness of Fins : 0.50 TCT MM 4) Mounting arrangement H.D.G. I. 5) Bearings are covered with plastic caps. 6) Nominal Wind Pressure : 80KM/HR. 7) RPM Capacity: 500 RPM 8) Yield Strength : 240 MPA 9) Glow Bands Marking on the borders of the Fins for Safety and Visibility in Night 10) Corrosion Resistant, Light Weight, Flexible Design, Rust Proof, Excellent Finished 11) At bottom side anti nest and anti-rusting GI net should be there.</p>	NO.	279			

Note:- Please Clearly Mention Taxes & Other Conditions.

Note:- Rate should be quoted Inclusive of 1% Labour Cess & GST. You should quote the rate in figure reference with given schedule "A".

Yours faithfully,


Executive Engineer,
M.S.E.T.C.Ltd,
EHV O&M Dn, Sangli