

**From: Office of The Executive Engineer
EHV (O&M), MSETCL Dn.
220 kV Jalna sub-station premises, MIDC, Jalna
E-mail:ee2170@mahatransco.in.**

No.EE/EHV (O&M)/Jalna/Tech/T / 0 . 1 7 9 Date: 17 MAR 2023

E-Enquiry

Sub- E-Enquiry for the Work of Repair of Control Room Point Wiring along with replacement of old type light fitting with new LED Panels at 132kv Mahakala Sub-station under EHV (O&M) Division, MSETCL Jalna.

Dear Sir/Madam,

This office is inviting sealed firm quotations in 2 bids system (Technical & Commercial) for above subjected works. Please Quote Your Lowest Rates in Line With Annexure – A enclosed herewith, Subject following terms and conditions:

TERMS & CONDITIONS:

Bidder should submit the 2 Nos of Sealed envelopes i.e.


1. First envelope containing Technical Documents must be Superscripted as **Technical Bid** for Work of Repair of Control Room Point Wiring along with replacement of old type light fitting with new LED Panels at 132kv Mahakala Sub-station under EHV (O&M) Division, MSETCL Jalna.
2. Second envelope containing Commercial offer in line with Annexure A must be Superscripted as **Commercial Bid** for Work of Repair of Control Room Point Wiring along with replacement of old type light fitting with new LED Panels at 132kv Mahakala Sub-station under EHV (O&M) Division, MSETCL Jalna.

Quotation should reach this office up to Dt. 24.03.2024 at 10:30 AM and will be opened on the same day if possible.

- Technical Bid will be opened first, thereafter only Technically Qualified bids will be eligible for commercial bid opening. Technically disqualified bids will not be opened.
- Single Bids will not be considered.
- Rate should be valid for 365 Days.
- Rates should be quoted in figures clearly
- The following Technical Documents should be attached along with technical bid:-
 - 1) Shop Act Registration/NOC from Grampanchayat
 - 2) GST Registration
 - 3) Valid Electrical Contractor License
 - 4) PAN Card
 - 5) Relevant Experience Certificate issued not below the Rank of Executive Engineer in MSETCL.
 - 6) Undertaking 1,2 &3 on your company letter head & undertaking 4 on Rs.500/- Non Judicial Bond.

Thanking you

Encl: - Annexure-A & undertakings1,2,3&4


**Executive Engineer,
EHV (O&M) Division, MSETCL,
Jalna.**

Copy.s.w.rs.to:-

- 1) The Superintending Engineer, EHV (O&M) Circle, MSETCL,A'bad.


Copy to:-

- 2) The Dy. Manager (F&A), Trans (O&M) Division, MSETCL, Jalna.

Annexure A

Sr.No.	Description	Qty	Unit	Rate with L. Cess	Amount
1	Supplying & erecting mains with 2x1.5 sq.mm FRLSH copper PVC insulated wire laid in provided conduit/trucking/inside pole/Bus bars or any other places. As per specification No. WGMA/BW.	360	Mtr.	40	14400
2	Supplying & erecting mains with 2x2.5 sq.mm FRLSH copper PVC insulated wire laid in provided conduit/trucking/inside pole/Bus bars or any other places. As per specification No. WGMA/BW.	120	Mtr.	62	7440
2	Supplying and erecting HMS PVC conduit FRLS grade 25 mm dia. With necessary accessories in wall/floor with chiseling appropriately as per specification No: WG-MA/CC.	40	RMT	127	5080
3	Supplying and erecting Ceiling rose / Batten holder / Slanting holder /hanging cord switch / hanging bell push / pendant holder Bakelite base6A. erected on filled polypropylene board or polished double wooden block/PVC junction box.	20	EA	39	780
4	Supplying and erecting PVC Surface modular switch box with double mounting plate for 2 modules duly erected.	4	EA	128	512
5	Supplying and erecting PVC Surface modular switch box with double mounting plate for 6 modules duly erected.	2	EA	222	444
6	Supplying and erecting PVC Surface modular switch box with double mounting & front plate for 8 modules complete duly connected.	15	EA	262	3930
7	Supplying and erecting PVC Surface modular switch box with double	8	EA	343	2744
8	Supplying and erecting shockproof 3 pin plug socket 16A with porcelain base/flush type erected on filled polypropylene (IS:14772-2000) board or polished thick varnished double wooden block / folded or screwed board with top of either wooden/3 mm thick hylam sheet/ 4mm thick plywood pasted with 1.5 mm thick laminate with S M screws and duly connected.	15	EA	59	885
9	Supplying & erecting triple pole and neutral distribution board (TPNDB), SPMCB of 12 ways /phase (36 poles), with door, 1.2mm thickness surface/flush mounted, IP 43 Protection on iron/GI frame (horizontal busbar type) as per specification no. SW-SWR/MCBDB	1	EA	4609	4609
11	Supplying and erecting modular type 3 pin 6 / 16A multi socket with safety shutter, duly erected on provided plate and box with wiring connections complete.	15	EA	160	2400
12	Supplying and erecting regular/ standard model ceiling fan of 1400mm. sweep complete erected in position as per specification no. FG-FN/CF.	9	EA	2275	20475

13	Supplying and erecting integrated LED street light having 18 to 22W IP65 & IK08 class having single piece pressure die-cast aluminum housing, having system lumens output of Min. 1800 Lumens, min. efficacy of 100 lumen/W, CRI>70, CCT up to 6500K, THD<10%, p.f. >0.95, operating range of 140-270V, inbuilt surge protection of 10 kV, Life class of 50,000 Hrs. at L70B50, including driver complete with 3 Years warranty as per specification No FGODF/FLS2.	4	EA	1929	7710
14	Supplying and erecting Street light bracket for erection of Double fitting on tubular welded pole with 40 mm. dia 1.0 m. length "B" class G.I. pipe along with pole cap of 125mm dia 600 mm long duly welded as per specification no. FG-BKT/BPC	6	EA	2154	12924
15	Point wiring in PVC trucking (casing-capping) with 1.5 sq.mm (2+1E) FRLSH grade copper wire, flush type switch, earthing and required accessories as per specification No: WG-PW/SW	25	Point	365	9125
16	Supplying and erecting LED square / circular Max. 25 W down lighter/ Panel Light having pressure die-cast aluminum housing, polystyrene diffuser having system lumens output of Min. 2750 Lumens, min. efficacy of 110 lumen/W, CRI>80, CCT upto 6500K, Beam Angle of 120 deg., max. ripple of 5%, THD<10%, p.f. >0.95, operating range of 120-270V, surge protection of 2.5 kV, Life class of 50,000 Hrs. at L70B50, including driver, having mounting arrangement with board for surface type or spring loaded mounting clips complete with 3 years warranty.	35	EA	1951	68285
Total Rs.					161749
Add 18% GST					29114.82
TOTAL RS.					190863.82


Executive Engineer,
EHV (O&M) Division, MSETCL,
Jalna.

Undertaking – 1

Validity of offer

I/We hereby declare that I am /We are participating in E-Enquiry No. _____ published by the Executive Engineer, EHV (O&M) Division MSETCL, Jalna .

I / We agree to execute this contract detailed as per the Terms & Conditions of the tender booklet attached with this E-Enquiry which I / we have carefully read and which I / we have thoroughly understood and to which I / we hereby agree.

I / We hereby declare that I am / we are the authorized signatory for this E-Enquiry on behalf of the firm.

I / We take sole responsibility arising out of any dispute from this issue.

I / We hereby agree to keep this offer open& valid for 120 (one hundred twenty) calendar days from the date of commercial opening of the tender.

Yours faithfully,

Seal and Signature of the Bidder

Date :

Address:

Undertaking – 2

‘Not Debarred/Blacklisted by any of the Government/Semi-Government/Other Public Sector Utilities’

I/We hereby declare that I am /We are participating in Enquiry No. _____ published by The Executive Engineer, EHV (O&M) Division MSETCL, Jalna.

As on date of submission of this E-Enquiry , I/ we hereby declare that my / our firm is not debarred/ blacklisted by any of the Government / Semi-Government / Other Public Sector Utilities, anywhere.

The above declaration is true to the best of my/ our knowledge and belief.

I/ We hereby agree that in case my / our firm is found debarred/ blacklisted by any of the Government/ Semi-Government/Other Public Sector Utilities, anywhere, my/ our offer is liable for rejection at any stage of the tendering process as per tender terms & conditions.

Further, I/ whereby understand and agree that incase my/ our firm is found debarred/ blacklisted by any of the Government/ Semi-Government/Other Public Sector Utilities, anywhere, my/ our work / purchase order is liable for termination at any stage of execution process and my / our firm shall be solely responsible for the consequences arising out of it.

**Authorized
Signatory**

Seal of the Firm

Undertaking – 3

Contact & Correspondence details

1	The name and full postal address for correspondence of the Firm / Company participating in this E-Tender	
2	The name and full postal address for correspondence of Proprietor / Partners / Director of the Firm / Company	
3	Name and Contact Number of the Contact Person	

Note – It will be the sole responsibility of the bidder to update / renew communication details (correspondence address, e mail, contact numbers, name change of an individual, firm, changes in Memorandum / Article of Association etc.) The Company accepts NO responsibility in case of any delay / loss thereof because of non-updating.

Seal and Signature of the Bidder

Date :

Address:

Undertaking – 4

Liabale for penal action under IPC

Affidavit (on Rs. 500/- Non Judicial Stamp Paper)

I

.....
age

..... address

.....
..... (Authorized signatory to offer bid & sign this contract), hereby submit,
vide this affidavit in truth, that I am the sole owner / authorized signatory of the firm

.....
..... which is bidding for this Enquiry No.
published by The Executive Engineer, EHV (O&M) Division, Jalna and I am submitting the
documents – technical & commercial – for the purpose of scrutiny of this bid.

I hereby agree that :-

1. I am liable for action under Indian Penal Code for submission of any false / fraudulent paper / information submitted with this offer.
2. I am liable for action under Indian Penal Code if during contract period and defect liability period, any false information, false bill of purchases supporting proof of purchase, proof of testing submitted by my staff, subletting company or by myself, I will be liable for action under Indian Penal Code.
3. I am liable for action under Indian Penal Code if any of the document / paper are found false / fraudulent during contract period and even after the completion of contract (finalization of final RA bill).

Date :-

Place :-

(Seal of the Company)(Signature of contractor)