

## **Amendment No. 5**

**SRM e-tender No. : T-1746 - Establishment of 400/220 KV GIS substation at Nashik (Eklahare), Dist., Nashik, under Nashik Zone. (RFx-6000000269)**

The bidders are requested to read following Amendment:

**Point No. 1 :** The various points raised by the various agencies concerning to items description of Supply Price schedule Sr. No 3 .1 to 3.4 & 9.1 to 9.3 are amended as below:

<b>Sr. No.</b>	<b>Item Description</b>
3.1	Bus duct to be considered for 400KV Line of appropriate ratings
3.2	Bus duct to be considered for 400KV ICT of appropriate ratings
3.3	Outdoor type SF6 termination bushing to be considered for Line
3.4	Outdoor type SF6 termination bushing to be considered for ICT
9.1 (i)	Bus duct to be considered for 220 KV side of ICT of appropriate ratings
9.1 (ii)	Bus duct to be considered for 220 KV side of Line of appropriate ratings
9.2	Outdoor type SF6 termination bushing to be considered for ICT
9.3	Outdoor type SF6 termination bushing to be considered for Line

**Point No. 2 :** The various points raised by the various agencies concerning to items description of Supply Price schedule Sr. No 7 .4 (i), 7.4 (ii) & 8 .3 (i), 8.3 (ii) are amended as below:

- a) Reply for the above said is as- the said 400kV & 220kV Isolators are to be provided for Rapid Restoration Scheme (RRS for spare ICT) as per actual requirement.
- b) 400kV & 220kV Aux. AIS type bus to be formed/provided for RRS.

**Point No. 3 :** Scope of cable between OCR & GCR is not considered.

**Point No. 4 :** Revised Layout in CAD format & Layout of Sinner side is uploaded.

**Point No. 5 :** The description in BOQ can not be change and is to be interpreted/read as per Amendments/Clarification only.

**Point No. 6 :** Supply Price schedule Sr. No 27 Structure Steel – To be considered as 350 MT and cost therefor to be considered proportionately.

**Point No. 7 :** Reply of queries received after Amendment No 4 .

**Note: 1) The Point No.1, 2 & 6 will be applicable in respective of ETC items.**

**2) The previous Replies/Amendments in respect of above points stands superseded**

The bidders are requested to check the details on our SRM e-tender webpage  
<https://srmetender.mahatransco.in>.

Chief Engineer  
(Design, Contracts & Monitoring)