

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.**  
**(CIN No.U40109MH2005SGC153646)**

**Name of Office:** Central Purchase Agency,  
**Office Address:** Prakashgad, 1<sup>st</sup> Floor, Plot No G-9, Anant Kanekar Marg Bandra (East),  
Mumbai-51  
**Contact No.:** 022-26474211/26472131  
**Email Id:** cecpa@mahatransco.in  
**Website:** www.mahatransco.in

SP/T-0703/0818

Date: 11.09.2018

AMENDMENT NO. - I

**Sub:** Procurement of VRLA Battery Sets for various Zones against e- Tender No. SP/T-0703/0818 [RFx. No. 5\*662] – **Clarification to bidders queries and Extension in due date of submission and opening of bid thereof.**

Dear Sirs,

Please refer e-Tender No. SP/T-0703/0818 [RFx. No. **5000000662**], advertised for procurement of VRLA Battery Sets.

In the Clause no. 9.0 “Capacity” and in Sr. No. 4 of Principle Technical Particulars (Annexure IA) of Technical Specification, the No. of Cells required for **384 V Battery Set** is not mentioned. The same is incorporated as **192 Cells (minimum)**.

Further, the voltage rating of battery at Sr. Nos. (4) & (5) of Annexure - F is erroneously indicated as 107 V. The same is corrected as **110 V**. Accordingly the revised Annexure-F (Confirmation for Item Quoted, Delivery & Delivery Schedule) is enclosed.

Further, the due dates of submission and opening of Tender are hereby modified as under:

Due date and time of submission of bids: 19.09.2018 up to 15.00 Hrs

Due date and time of opening of bids: 19.09.2018 at 15.30 Hrs

All participant bidders are requested to take note of the above and submit their bids accordingly. All other terms and conditions of the Tender specifications remain unchanged.

Yours faithfully,  
-sd-  
Executive Engineer (St. VIII)