

Annexure-A
Clarifications on Pre- Bid Queries-I

Sr.No.	Reference	Pre- Bid Query of Bidder	MSETCL's Clarifications
1	Clause No. 5.4 of Technical Specification- The post insulators shall have a creepage distance of 25mm per kV of highest system voltage.	Considering various substations in Maharashtra, the given 25mm per kV creepage Distance is applicable for all substations or not. Kindly confirm.	Shall be as per MSETCL's Technical Specification.
	Technical Specification Clause No. 1.0 Scope- for installation in various substations in Maharashtra State (India).		
2	Annexure-B1 i.e. Price Break-up - 420kV, 3150A, 50kA Pantograph Isolator complete with insulator & Lattice Type Support Structure	Please confirm the required 420kV Pantograph isolator is with Earth Switch or without Earth.	Shall be without Earth Switch.

Sd/-
Executive Director (Operations)