

Annexure 'A' (Reply to Pre-bid Queries)

Tender No. i) T-2319/MSETCL/CO/Projects/Pre-tender Pkg-A (Rfx no. 6000001100),
ii) T-2320/MSETCL/CO/Projects/Pre-tender Pkg-B (Rfx. No. 6000001110)

Name of Work i) Balance work for 400kV D/C Jejuri - Winjhar (Loc. 148) line i.e. LILO point of 400kV Lonikand-I - Koyna Stage-IV ckt II to Winjhar (Loc. 148)- 36.88 km Package- A under Pune Zone
ii) Balance work for 400kV D/C Hinjewadi – Winjhar line (from Loc. 148) – 33.577 km Package- B under Pune Zone

All queries should be emailed on : ee13prj@mahatransco.in; se6prj@mahatransco.in; cecm@mahatransco.in

Sr. No.	Type	Ref. Document	Clause No.	Sub-Clause No.	Page No.	Existing Clause	Bidder's Query	MSETCL's Reply
1	Tendering	Other	2		1	Scope of work:- i) Balance work for 400kV D/C Jejuri - Winjhar (Loc. 148) line i.e. LILO point of 400kV Lonikand-I - Koyna Stage-IV ckt II to Winjhar (Loc. 148)- 36.88 km Package- A under Pune Zone ii) Balance work for 400kV D/C Hinjewadi – Winjhar line (from Loc. 148) – 33.577 km Package- B under Pune Zone	1. According to the scope of the tender, it is the balance pending work, which has to be completed. There is severe ROW and thereby would hamper the progress of the work. Tower quantity required is very less considering the project size (40 Nos only) and there by not possible to procure the tower material in phases as linked by various interlocks like Row clearnace, Foundation activity done etc. Hence, considering all these points, there is possiblity that the given Activity schedule (Having Interlinking) may not be followed and hence requested to delete the interlinking activity from the Activity schedule.	Accepted, bidder should adhere to the time line mentioned in the Activity Schedule for timely completion of project
2	Tendering	Other					2.While survey of this work , it is observed that almost 50 to 70% of towers are located in the hilly terrian. The activity to consider approach road or head loading needs to be added to justify the work completion in schedule time and cost is not considered in Price Schedule.	Will be considered seperately as per actual site condition with due approval of SE (Project), MSETCL
3	Tendering	Other					3.The towers are to be procured as per approved survey. However after procurement of tower and during execution of work if type of tower is required to change due to site constraints or due to ROW, the previously procured towers may become spare and may not be used in the said project. Under circumstances MSETCL shall takeover the spare tower for maintenance purpose and 100% payment towards this spare towers shall be released immediatley.	Not accepted