

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
[CIN:U40109MH2005SGC153646]

OFFICE OF THE CHIEF ENGINEER
Transmission O&M Department,

**'Prakashganga', MSETCL, Plot No. C-19, E- Block, Bandra Kurla Complex,
Bandra(E), Mumbai-400051 (Maharashtra), India**

Phone: (022)-26595159 (Direct)
(022)-26595171 (Office)
(022)-69852717 (Office)

e-Mail : ceom@mahatransco.in ;
eegrp5@mahatransco.in

Website: <https://www.mahatransco.in/>

No. SP/T-0508/1222/

No 01101

Date: 11 DEC 2023

By R.P.A.D. /Extra copy by Ordinary Post/e-Mail

LETTER OF AWARD

To:

**M/s. Mehru Electrical & Mechanical Engineers Pvt. Ltd.,
Phase I, Extension Ghatal, E -1247 RIICO Industrial Area, Bhiwadi,
Rajasthan- 301019**

Phone: 01493-222010

e-mail: mehruworks@vsnl.com ; sales@mehru.net

Vendor ID: 4000000216

Status: LSI(O)

GSTIN : 08AABCM2145G1ZR

Sub:- Supply of 145kV and 245kV Class Live Tank Current Transformers of various Ratios and 145kV Class Potential Transformers for R&M Scheme under Amravati, Chhatrapati Sambhajinagar, Nagpur, Karad & Pune Zone and LE Scheme under Karad & Nagpur Zone through e-Tender No. SP/T-0508/1222 (RFx 5000001089) opened on 18.01.2023 and Price Bid Opened on 21.07.2023

Ref:- 1) Your On-line Response 4000136330 read with Offer No. MSETCL/T-508/5000001089/2022-23 Dt.05.01.2023 and modified up to date
2) Deviation Bid opened On-line on 24.02.2023 @ 12:55 Hrs.
3) Matching Bid opened Offline on 24.07.2023 @15:00Hrs.

---X---

Dear Sirs,

This is with reference to our e-Tender No. SP/T-0508/1222 (RFx 5000001089) for the Procurement of 145kV & 245kV Class Live Tank Current Transformers of various Ratios and 145kV Class Potential Transformers opened on 18.01.2023.

Your offer/ e-Tender submitted electronically, modified up to date is hereby accepted.
Details thereof are as under:

Sr. No.	Item No.	Item Description	Quantity Awarded (Nos.)	Unit FOR-D Rate (₹)	Delivery Schedule
1	2	3	4	5	6
1	1	145kV,800-400-200/1A, 5C Live Tank CT [500025306]	156	1,55,760.00 (Matched) 1,65,200.00 (Quoted)	CM: 08 Nos. within Two (02) Months from the Date of LoA CP: @ 100 Nos. per Month thereafter
2	2	145kV, 2400-1200/1A, 5C Live Tank CT [500025302]	19	2,00,600.00 (Own Rate)	CM: 04 Nos. within Two (02) Months from the Date of LoA CP: @ 10 Nos. per Month thereafter
3	3	145kV, 800-400/1A, 5C Live Tank CT [500025112]	22	1,41,600.00 (Matched) 1,50,450.00 (Quoted)	CM: 05 Nos. within Two (02) Months from the Date of LoA CP: @ 12 Nos. per Month thereafter
4	4	245kV,800-400-200/1A, 5C Live Tank CT [500023710]	15	3,89,400.00 (Own Rate)	CM: 05 Nos. within Two (02) Months from the Date of LoA CP: @ 12 Nos. per Month thereafter
5	5	245kV, 1200-600/1A, 5C Live Tank CT [500025307]	04	3,83,500.00 (Matched) 3,89,400.00 (Quoted)	CM: 03 Nos. within Two (02) Months from the Date of LoA CP: @ 03 Nos. per Month thereafter
6	6	145kV, (132-110/√3)/ (110/√3) 3C PT [500000644]	13	1,41,600.00 (Matched) 1,47,500.00 (Quoted)	CM: 04 Nos. within Two (02) Months from the Date of LoA CP: @ 07 Nos. per Month thereafter

...3

Sub: Supply of 145kV & 245kV Class Live Tank Current Transformers of various Ratios and 145kV Class Potential Transformers for R&M Scheme under Amravati, Chhatrapati Sambhajanagar, Nagpur, Karad & Pune Zone and LE Scheme under Karad & Nagpur Zone through e-Tender No. SP/T-0508/1222 (RFx 5000001089) opened on 18.01.2023 and Price Bid Opened on 21.07.2023

The Routine/Acceptance Tests shall be conducted at Manufacturer's Works. The Manufacturer's Testing Lab shall have NABL Accreditation. All the Equipment used for Testing should have valid Calibration on the date of Testing.

Manufacture shall have In-House Routine Test Facilities (As per IS 16227 and IEC: 61869) and Test Facility for Temperature Rise Test, Lightning Impulse Test and Composite Error Test by Direct Method (for Ensuring Low Reluctance of PS Core).

The Manufacture shall carryout Lighting Impulse Test & Temperature Rise Tests on One random selected CT/PT of each Lot of 25 Nos. of every Item. In case, the Lot size is less than 25 Nos., then also it shall be mandatory to conduct aforesaid Test on One sample from such Lot.

In case the Manufacture does not have In-House Facility for carrying out Lightening Impulse Test then same can be carried out at other Facility (i.e NABL Accredited Lab), in presence of MSETCL's Representative.

All expenditure for carrying out Lightening Impulse Test outside the Manufacturer's Work shall be borne by the Bidder including Charges (Inclusive of TA & DA) towards Deputation of MSETCL's Representative. In case the CT/ PT does not pass the Test successfully, the entire Lot will be rejected.

The Delivery Schedule i.e. Commencement and Completion of Item awarded to you is indicated in Column No. 6 of above Table.


As agreed by you, the above including all other Terms & Conditions of Bid Document, the Commencement Period of Delivery includes period required for submission and approval of all Contractual Drawings, Test Reports, QAP and Inspection etc.

Therefore as per Clause No. Clause No. 10.0 of Technical specifications (Annexure 'D'), Final Version of all the Drawings in Hard as well as AutoCAD Format; Information regarding QAP Bill of Material/Packing List; Type Test Report etc. shall be submitted to the Office of the Chief Engineer (Design), M.S.E.T.C.L., "Prakashganga", Bandra (East), MUMBAI-51 for approval immediately after receipt of this Letter of Award.

Detailed Order follows.

Please convey your acceptance by return Letter/e-Mail.

Yours sincerely,


[SUNIL SHEREKAR]
Chief Engineer (Trans. O&M)

...4

Copy s.w.rs. to:-

- 1] The Director (Operations), MSETCL, "Prakashganga", Mumbai
- 2] The Executive Director (Operations), MSETCL, "Prakashganga", Mumbai

Copy f.w.cs to:-

- 1] The Chief General Manager (F&A), MSETCL, "Prakashganga", Mumbai
- 2] The Chief Engineer (Design), MSETCL, "Prakashganga", Mumbai
- 3] The Chief Engineer, EHV PC O&M Zone,
Amravati/ Chhatrapati Sambhajinagar /Karad/Nagpur/Nashik/Pune/Vashi
- LE Scheme for Nagpur Zone Sanctioned vide ED (Trans) No. 3823 Dt.18.11.2021
LE Scheme for Karad Zone Sanctioned vide Dir. (Ops)/606 Dt.11.03.2022
R&M Spares for Karad Zone Sanctioned vide - CE/KRD/ADM/R&M/61/2021-22
ED (Ops)/396 Dt.19.07.2022
CE/KRD/ADM/R&M/32/2022-23
R&M Spares for Nagpur Zone Sanctioned vide ED (Ops)/3910 Dt.08.12.2021
R&M Spares for Amravati Zone Sanctioned vide MBR No.141/08 Dt.26.06.2020
R&M Spares for Chhatrapati Sambhajinagar Zone Sanctioned vide MBR No.141/08 Dt.26.06.2020
R&M Spares for Pune Zone Sanctioned vide ED (Ops)/3809 Dt.11.11.2021

Copy to:-

- 1] The General Manager (F&A-CA), MSETCL, "Prakashganga", Mumbai
- 2] The Superintending Engineer (Trans. O&M-II), MSETCL, "Prakashganga", Mumbai
- This has reference to Indent vide Office Note No. MSETCL/CO/Trans. O&M/EE-VI/
Procurement/E.D. (Ops)/1494 Dt. 07.12.2022 received on 08.12.2022 [PR No. 20001392]
read with e-Mail Dt.13.12.2022 @15:11 Hrs. from <se2om@mahatransco.in>
- 3] The Assistant General Manager (F&A-CF), MSETCL, "Prakashganga", Mumbai
- 4] The Executive Engineer (Trans.O&M-VI), MSETCL, "Prakashganga", Mumbai
- 5] The Executive Engineer (P&C), MSETCL, "Prakashgad", Mumbai
- 6] The Executive Engineer, Major Stores,
Badnera/Baramati/Karad/Dharashiv/Padegaon/Wardha
- 7] The Senior Manager (F&A-SB), MSETCL, "Prakashganga", Mumbai
- 8] The Manager (F&A- SP), MSETCL, "Prakashgad", Mumbai

LOA- 29 Dt.11.12.2023

Approved by the Hon. Chairman and Managing Director in consultation with
Director (Operations) and Director (Finance) vide CMD/MSETCL/NO. 990 Dt.04.12.2023

Sub: Supply of 145kV & 245kV Class Live Tank Current Transformers of various Ratios and 145kV Class Potential Transformers for R&M Scheme under Amravati, Chhatrapati Sambhajinagar, Nagpur, Karad & Pune Zone and LE Scheme under Karad & Nagpur Zone through e-Tender No. SP/T-0508/1222 (RFx 5000001089) opened on 18.01.2023 and Price Bid Opened on 21.07.2023