

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED**  
**CIN No. : U40109MH2005SGC153646**

**Name of Office:** Central Purchase Agency,  
**Office Address:** Prakashgad, 1<sup>st</sup> Floor, Plot No G-9, Anant Kanekar Marg, Bandra (East),  
Mumbai-51  
**Contact No.:** 022-26474211/26472131  
**Email Id:** [cecpa@mahatransco.in](mailto:cecpa@mahatransco.in)

SP/T-0632/0924

Date: 10.09.2024

**CLARIFICATION**

Sub:- Procurement of 33kV Class CBs (Circuit Breakers) under LE for EHV Substations under Nashik Zone of MSETCL [1<sup>st</sup> call] against e-Tender No.SP/T-0632/0924 (Rfx No.5000001286) submission due on 12.09.2024.--- **Reply to Pre-Bid queries thereof.**

Please refer e-Tender No. SP/T-0632/0924 (Rfx No. 5000001286) advertised for subject works.

Bidders are requested to take a note that the **Reply to the Pre-Bid Queries** is attached herewith as “ANNEXURE-A” .

The Due dates of Submission and Opening of Tender are as under:

- i) Due date and time of Submission of bid : 12.09.2024 upto 17:00 Hrs.
- ii) Due date and time of Opening of bid : 12.09.2024 at 17:15 Hrs.

All participants bidders are requested to take note of above and submit their bids accordingly. All other terms & conditions of the Tender Specifications remain unchanged.

Sd/-  
Executive Engineer (St-VI)

## ANNEXURE-A

<b>Sr. No.</b>	<b>Particulars</b>	<b>CL No.</b>	<b>MSETCL Specs</b>	<b>Proposed TS</b>	<b>MSETCL's Reply</b>
<b>Technical Requirements</b>					
1	Type Test	CL No. 7.1.1 Type Test	<p>All the equipments offered shall be fully type tested in accredited test laboratory as per the relevant standards, amended up-to-date. Type tests conducted in India shall be from NABL (National Accreditation Board for testing and calibration Laboratories) accredited testing laboratories.</p> <p>These tests must not have been conducted earlier than ten years from the date of opening of bids except for the tests for which testing facility is not available in India. However, such tests (i.e. for which testing facility is not available in India) should have been carried out successfully as per IEC 62271-100 standards amended upto date.</p> <p>In case the type tests are conducted earlier than ten years, all the type tests except for the tests for which testing facility is not available in India, shall be carried out by the successful bidder in an accredited test laboratory in presence of purchaser's representative free of cost before commencement of supply. Bidder shall give the purchaser three weeks advance intimation to enable him to depute his representative for witnessing such Type Tests.</p>	<p>All the equipments offered shall be fully type tested in accredited test laboratory as per the relevant standards, amended up-to-date. All the Type tests conducted shall be from NABL (National Accreditation Board for testing and calibration Laboratories) accredited testing laboratories i.e. CPRI/ ERDA in India only.</p> <p>However, only those tests for which testing facility is not available in India should have been carried out successfully at International Labs having accreditation of that country .</p> <p>These tests must not have been conducted more than five years from the date of opening of bids.</p>	Shall be as per Technical Specification.