

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
[CIN:U40109MH2005SGC153646]

OFFICE OF THE SUPERINTENDING ENGINEER
Central Purchase Agency,

**‘Prakashgad’, 1st Floor, Plot No. G-9, Anant Kanekar Marg,
Bandra (East), Mumbai-400051**

Phone: (022)-69852740 (Office)
(022)-69852717 (Office)

e-Mail : secpa @mahatransco.in ;
eegrp5@mahatransco.in

Website: <https://www.mahatransco.in/>

SP/T-0519/0924/

Date:12.09.2024

CLARIFICATIONS ON PRE-BID QUERIES-1

Sub: Procurement of 500MVA, 765/400/33kV, 1- ϕ ICT (03 Nos.) alongwith Virgin High Grade Inhibited Insulating Oil conforming to IEC 60296 for 765kV R.S. Ektuni Sub-Station under Augmentation Scheme at Chhatrapati Sambhajinagar Zone against e-Tender No. SP/T-0519/0924 (RFx 5000001279), Submission and Opening Due on 19.09.2024- 2nd Call

Ref: Pre-Bid Meeting scheduled on 09.09.2024 at ‘Prakashganga’, MSETCL, Mumbai

Bidders are requested to refer the Annexure-A attached herewith for Clarifications on Commercial and Technical Pre-Bid Queries against the subject e-Tender and submit their Bids accordingly.

This is issued without prejudice to all other Terms & Conditions of the subject e-Tender.

This Notification is published on SRM Portal viz. <https://srmetender.mahatransco.in/> and MSETCL Portal viz. <https://www.mahatransco.in/>

Encl: Annexure-A

Sd/-
Superintending Engineer (CPA)

Annexure-I
Clarifications on Pre- Bid Queries-I

Sr.No.	Reference	As per Tender document	Pre- Bid Query of Bidder	MSETCL's Clarifications
1	2	3	4	5
1	<u>Section-III</u> Clause No. 6 Delivery Period	Commencement: 1 No. within Fourteen (14) Months from the Date of LoA Completion: @ 1 No. per Month thereafter	Delivery commencement for 400kV, 765kV Transformers & reactors at least 24 months.	NO CHANGE
2	<u>Section-III</u> Clause No. 2 PRICES & PRICE VARIATION	<p>i) The Price Variation shall be calculated from the date of opening of Techno-Commercial bid of the tender.</p> <p>Note-</p> <p>a) For computation of PV the 'date of opening' referred above / in IEEMA PV Circular shall be the 'published' date (including extension, if any) of opening of Techno-Commercial bid of the tender till which time the bidder had the option to modify his quoted price and not the 'actual' date on which the Techno-Commercial bid of the tender is opened.</p> <p>ii) The Price Variation shall be calculated as per IEEMA PV Formula and monthly indices published by IEEMA.</p> <p>iii) For supplies effected / works completed within the contractual period, the Price Variation will be payable as per above clauses.</p> <p>iv) In case of contract / Order completed / executed beyond the contractual period, the Price Variation will be payable for the supplies effected / works completed within the contractual period. For balance supplies effected / works completed after the contractual period, Price Variation will be payable as per above clauses, only for the extended time period approved by the Competent Authority.</p> <p>Note-</p> <p>a) The MSETCL shall not be liable for any additional cost incurred by the Contractor on account of price variation for supplies effected / completion of works beyond the original contract period, on account of default by Contractor. However, in such case, if PV calculated for this period is negative then same will be deducted / recoverable from agency.</p> <p>b) PV shall be payable beyond the original contract period, if time extension is granted as per provisions of GTC Clause due to force majeure conditions or due to delay/defaults on account of MSETCL, subject to the conditions that same has been considered by competent authority based on the documentary evidence furnished for granting Time Limit Extension with PV and subsequently a Time Limit Extension Letter is issued with PV by MSETCL.</p> <p>c) The 'date of delivery' shall be the date on which the equipment / material is notified as being ready for inspection / dispatch or the contracted delivery date whichever is earlier whenever supplies are effected within contractual delivery period. In case the supplies are effected after the contractual delivery period, the date of the delivery for Price Variation purpose would be one out of the two on which the price variation is less.</p>	Price Variation shall be payable upto contractual delivery period for delayed supplies. Revised PVC clause not clear.	Note a) and b) under Clause No. 2 (c) (iv) of Section-III shall be referred.
3	<u>Technical Specification</u> Clause No. 1.4.29.8 Accessories	The equipment shall be supplied with all necessary accessories required for carrying out on-line DGA of transformer oil complete in all respect as per the technical specification.	Online DGA - This is an imported item and Bidder is facing severe issues / difficulty in getting service support after sales / timely delivery from the vendors. MSETCL is requested to remove item online DGA from our scope of supply and procure this item directly from overseas supplier, if required.	NO CHANGE

Sd/
Superintending Engineer (CPA)