

**MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED**  
[ CIN:U40109MH2005SGC153646 ]

**OFFICE OF THE SUPERINTENDING ENGINEER**  
Central Purchase Agency,

**'Prakashgad', 1st Floor, Plot No. G-9, Anant Kanekar Marg,  
Bandra (East), Mumbai-400051**

**Phone:** (022)-69852740 (Office)  
(022)-69852717 (Office)

**e-Mail :** secpa @mahatransco.in ;  
eegrp5@mahatransco.in

**Website:** <https://www.mahatransco.in/>

SP/T-0521/0924/

Date:20.09.2024

**CLARIFICATIONS ON PRE-BID QUERIES-1**

**Sub:** Procurement of 400kV, 50MVA<sub>r</sub>, 3-Φ Switchable Line Reactor (5 Nos.) along with NGR; Surge Arrestor and New Uninhibited Naphthenic Based High Grade Mineral Insulating Oil required for 400kV Girawali Sub-Station under Chhatrapati Sambhajnagar Zone- 1<sup>st</sup> Call against e-Tender No. SP/T-0521/0924 (RFx 5000001290); Submission and Opening Due on 03.10.2024

**Ref:** Pre-Bid Meeting scheduled on 19.09.2024 @ 14:30 Hrs.at 'Prakashganga', MSETCL, Mumbai

----

Bidders are requested to refer the Annexure-A attached herewith for Clarifications on Commercial and Technical Pre-Bid Queries against the subject e-Tender and submit their Bids accordingly.

This is issued without prejudice to all other Terms & Conditions of the subject e-Tender.

This Notification is published on SRM Portal viz. <https://srmetender.mahatransco.in/> and MSETCL Portal viz. <https://www.mahatransco.in/>

**Encl:** Annexure-A

*Sd/-*  
**Superintending Engineer (CPA)**

**ANNEXURE-A**

**Clarifications on Pre- Bid Queries-I**

Sr. No.	Reference	As per Tender Document	Pre-Bid Query of Bidder	MSETCL's Clarification
1	Clause No. 2.0 of Section - III: Prices & Price Variation:	(c) A Ceiling / Capping of Twenty Percent (20%) on Positive Price Variation and no Ceiling / Capping on Negative Price Variation shall be applicable for the purpose of Payment of Price Variation as below.	Price Variation shall be payable upto contractual delivery period for delayed supplies. PVC to be without ceiling.	As per Tender Condition.
2	Clause No. 5.0 of Section - III: Delivery Period	Commencement : 1 No. within Ten (10) Months from the Date of LoA  Completion: @ 1 No. per Month thereafter	a) Commencement : 1 No. within Twenty Four (24) Months from the date of Drawing Approval & Completion: @ 1 No. in Three (03) Months thereafter  b) Delivery commencement for 400kV, Transformers & reactors at least 24 months.	No change
3	Clause No. 6.0 of Section III: Submission of Drawing, Bill of Material, QAP, Type Test Reports etc:	The Timeline for the Submission and Approval of Drawing & QAP is as under: i. Submission Time of Drawings/QAP for the Bidder after receipt of LoA Twenty Five (25) Days ii. Time Period for calling Revisions/Clarification thereon by MSETCL Eight (08) Days iii. The Time Period to Re-Submit the Revised Drawing/QAP by the Bidder Five (05) Days iv. Time Period for Final Approval of Drawings/QAP Fifteen (15) Days (Including the Time Period for calling Revision/Clarification)	The Timeline for the Submission and Approval of Drawing & QAP is as under: i. Submission Time of Drawings/QAP for the Bidder after receipt of LoA Forty Five (25) Days ii. Time Period for calling Revisions/Clarification thereon by MSETCL Eight (08) Days iii. The Time Period to Re-Submit the Revised Drawing/QAP by the Bidder Fifteen (15) Days iv. Time Period for Final Approval of Drawings/QAP Fifteen (15) Days (Including the Time Period for calling revision/Clarification)	No change
4	Clause No. 23.0 of Technical Specification	On-Line Multi Gas (9 Gases) DGA for Reactor Oil	Online DGA - This is an imported item and we are is facing severe issues / difficulty in getting service support after sales / timely delivery from the vendors. MSETCL is requested to remove item online DGA from our scope of supply and procure this item directly from overseas supplier, if required.	Not accepted

*Sd/-*  
**Superintending Engineer (CPA)**