

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED
[CIN:U40109MH2005SGC153646]

OFFICE OF THE SUPERINTENDING ENGINEER
Central Purchase Agency,

'Prakashgad', 1st Floor, Plot No. G-9, Anant Kanekar Marg,
Bandra (East), Mumbai-400051

Phone: (022)-69852740 (Office)
(022)-69852717 (Office)

e-Mail : secpa @mahatransco.in ;
eegrp5@mahatransco.in

Website: <https://www.mahatransco.in/>

SP/T-0527/1024/

Date:17.10.2024

CLARIFICATIONS ON PRE-BID QUERIES-1

Sub: Procurement of 200MVA, 220/132/11kV ICT (1 No.); 50MVA, 132/33kV Power Transformer (9 Nos.) and 50MVA, 220/33kV Power Transformer (1 No.) along with New Uninhibited High Grade Mineral Insulating Oil for Augmentation Schemes under Chhatrapati Sambhajnagar; Nashik and Pune Zone of MSETCL against e-Tender No. SP/T-0527/1024 (RFx 5000001307), Submission and Opening Due on 25.10.2024- 1st Call

Bidders are requested to refer the Annexure-A attached herewith for Clarifications on Technical & Commercial Pre-Bid Queries against the subject e-Tender and submit their Bids accordingly.

This is issued without prejudice to all other Terms & Conditions of the subject e-Tender.

This Notification is published on SRM Portal viz. <https://srmetender.mahatransco.in/> and MSETCL Portal viz. <https://www.mahatransco.in/>

Encl: Annexure-I

Sd/-
Superintending Engineer (CPA)

Annexure-I
Clarifications on Pre- Bid Queries-I

Sr.No.	Reference	As per Tender document	Pre- Bid Query of Bidder	MSETCL's Clarifications
1	2	3	4	5
1	Section-III Clause No. 6 Delivery Period	<p><u>Item 1: 200MVA, 220/132/11kV ICT</u> along with New Uninhibited High Grade Mineral Insulating Oil [500000371] Commencement & Completion: 1 No. within Six (06) Months from the Date of LoA</p> <p><u>Item 2: 50MVA, 132/33kV Power Transformer</u> along with New Uninhibited High Grade Mineral Insulating Oil [500017982] Commencement: 1 No. within Six (06) Months from the Date of LoA Completion: @ 2 Nos. per Month thereafter</p> <p><u>Item 3: 50MVA, 220/33kV Power Transformer</u> along with New Uninhibited High Grade Mineral Insulating Oil [500017985] Commencement & Completion: 1 No. within Six (06) Months from the Date of LoA</p>	Delivery commencement for 220KV transformers at least 10 months.	NO CHANGE
2	Section-III Clause No. 2(c) PRICES & PRICE VARIATION	A Ceiling / Capping of Twenty Percent (20%) on Positive Price Variation and no Ceiling / Capping on Negative Price Variation shall be applicable for the purpose of Payment of Price Variation.	Price Variation shall be payable upto contractual delivery period for delayed supplies. PVC to be without ceiling.	NO CHANGE
3	Technical Specification Clause No. 5.18 General Technical Requirements	On-Line Monitor for Transformer Oil (For 200MVA & above Rating)	Online DGA - This is an imported item and Bidder is facing severe issues / difficulty in getting service support after sales / timely delivery from the vendors. MSETCL is requested to remove item online DGA from our scope of supply and procure this item directly from overseas supplier, if required.	NO CHANGE

Sd/-
Superintending Engineer (CPA)