



MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LIMITED [CIN:U40109MH2005SGC153646]

OFFICE OF THE SUPERINTENDING ENGINEER Central Purchase Agency,

'Prakashgad', 1st Floor, Plot No. G-9, Anant Kanekar Marg, Bandra (East), Mumbai-400051

Phone: (022)-69852740 (Office) (022)-69852717 (Office) Website: https://www.mabatransco e-Mail : secpa @mahatransco.in ; eegrp5@mahatransco.in

Website: https://www.mahatransco.in/

SP/T-0530/1024/

Date:18.10.2024

CLARIFICATIONS ON PRE-BID QUERIES-1

Sub: Procurement of 200kVA,33/0.433kV (24 Nos.) and 200kVA,11/0.433kV (01 No.) Station Transformers along with HV/LV Terminal Connectors and Insulating Oil without Inhibitors conforming to the requirement of IS:335 Amended Up-to-Date under CAPEX Budget FY-2023-24 & FY-2024-25 for EHV PC O&M Zone, Nashik against e-Tender No. SP/T-0530/1024 (RFx 5000001320), Submission and Opening Due on 21.10.2024 - 2nd Call

Bidders are requested to refer the Annexure-A attached herewith for Clarifications on Technical Pre-Bid Queries against the subject e-Tender and submit their Bids accordingly.

This is issued without prejudice to all other Terms & Conditions of the subject e-Tender.

This Notification is published on SRM Portal viz. <u>https://srmetender.mahatransco.in/</u> and MSETCL Portal viz. <u>https://www.mahatransco.in/</u>

Encl: Annexure-I

Sd/- Superintending Engineer (CPA)

<u>Annexure-I</u> Clarifications on Pre- Bid Queries-I

Sr.No.	Reference	As per Tender document	Pre- Bid Query of Bidder	MSETCL's Clarifications
1	2	3	4	5
1	Technical Specification Clause No. 12.0 Qualifying Requirements For Bidders	 12.7 The tenderer shall furnish, with his bid, type test reports of tendered equipment/material of equal or higher voltage class. The type test reports of the collaborator for equipment/ material as above would also be considered for the purpose of these qualifying requirements. 12.9 The Tenderer who does not meet the above qualifying requirement of experience (clause 12.1, 12.4 and 12.5) may be considered for a Trial' order subject to fulfilling the following requirements alongwith clauses 12.2, 12.3 & 12.6. (a) The Tenderer should have type tested the tendered item/equipment. (b) The Tenderer shall have the basic infrastructure for the design, manufacture and supply of the tendered items offered, like machinery, technical know-how, capacity etc. (c) The purchaser is satisfied with the designing, manufacturing supplying and financial capacities of 	In the Tender MSETCL has asked for Offer of 200 KVA, 11/0.433 kV- 01 No Transformer. Bidder do not have Type Test of said Transformers also for 01 No. Transformer carrying out Type Test is not economical. Bidder therefore requested to waivel the type Test Clause for 01 No of 200 kVA, 11/0.433KV Transformer. MSETCL Tender quantity for 200 KVA, 11KV is 01 No. in the terms of Tender Bidder have to submit the Type Test for the item quoted. As Bidder do not have the Type Test for 200KVA, 11KV Station Transformer, Bidder is unable to quote the item unless MSETCL grant the waivel of Type Test. The Type Test charges including Short Circuit Test Fee is above Rs. 2.00 Lacs which is not economical for 01 No Transformer. Bidder requested to accord the waivel of Type Test for 200 KVA, 11 KV Station Transformer.	NO CHANGE
		the tenderer.	not have the Type Test of the same. The Quantity required by MSETCL is only 01 No. The Type Test charges are too high. Bidder requested to arrange to delete the Type Test Clause for 01 No Transformer and grant the waivel of Type Test.	

*Sd/-*Superintending Engineer (CPA)